

Radon Testing Results -SLSD Al Kennedy High School

Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Al Kennedy High School	Kennedy High School 4	PRINCIPAL	5113459	3/28/2021	Detector kit	3.2
Al Kennedy High School	Kennedy High School 4	OFFICE	5095553	3/28/2021	Detector kit	3.8
Al Kennedy High School	Kennedy High School 4	OFFICE	5094843	3/28/2021	Detector kit	4.1
Al Kennedy High School	Kennedy High School 4	OFFICE DUP	5113393	3/28/2021	Detector kit	3.4
Al Kennedy High School	Kennedy High School 4	HEALTH	5094811	3/28/2021	Detector kit	3.4
Al Kennedy High School	Kennedy High School 2	LIBRARY/Room 11	5113565	3/28/2021	Detector kit	3.1
Al Kennedy High School	Kennedy High School 2	LIBRARY/Room 11	5113408	3/28/2021	Detector kit	3.0
Al Kennedy High School	Kennedy High School 2	LIBRARY/Room 11	5113390	3/28/2021	Detector kit	3.8
Al Kennedy High School	Kennedy High School 2	LIB DUP/Room 11	5113597	3/28/2021	Detector kit	3.5
Al Kennedy High School	Kennedy High School 5	ROOM 1	5094848	3/28/2021	Detector kit	1.3
Al Kennedy High School	Kennedy High School 2	ROOM 7	5095472	3/28/2021	Detector kit	1.2
Al Kennedy High School	Kennedy High School 5	ROOM 2	5113351	3/28/2021	Detector kit	0.9
Al Kennedy High School	Gym	STAFF	5095419	3/28/2021	Detector kit	0.4
Al Kennedy High School	Gym	GYM	5094802	3/28/2021	Detector kit	1.0
Al Kennedy High School	Gym	GYM	5094877	3/28/2021	Detector kit	1.4
Al Kennedy High School	Gym	GYM	5113466	3/28/2021	Detector kit	1.2
Al Kennedy High School	Gym	GYM DUP	5113528	3/28/2021	Detector kit	1.4
Al Kennedy High School	Kennedy High School 1	3	5094961	3/28/2021	Detector kit	2.2
Al Kennedy High School	Kennedy High School 1	4	5094942	3/28/2021	Detector kit	2.0
Al Kennedy High School	Kennedy High School 1	5	5113522	3/28/2021	Detector kit	1.9
Al Kennedy High School	Kennedy High School 1	6	5113407	3/28/2021	Detector kit	2.0
Al Kennedy High School	Kennedy High School 1	8	5094835	3/28/2021	Detector kit	1.6
Al Kennedy High School	Kennedy High School 1	9	5113369	3/28/2021	Detector kit	<0.3
Al Kennedy High School	Kennedy High School 2	MODULAR	5113503	3/28/2021	Detector kit	<0.3
Al Kennedy High School	Kennedy High School 2	MODULAR	5113400	3/28/2021	Detector kit	<0.3
Al Kennedy High School	Kennedy High School 2	MODULAR DUP	5095467	3/28/2021	Detector kit	<0.3
Al Kennedy High School	Kennedy High School 4	OFFICE	5071920	10/19/2021	Retest	3.4

- The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.
- 2 spike/blank tests were conducted to ensure the integrity of the testing process and all spike/blank tests passed satisfactorily.

Radon Testing Results -SLSD Bohemia Elementary School

Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Bohemia Elementary School	Bohemia Elementary	CR 1	5095535	03/27/2021	Detector kit	0.7
Bohemia Elementary School	Bohemia Elementary	CR 2	5095404	03/27/2021	Detector kit	1.0
Bohemia Elementary School	Bohemia Elementary	CR 3	5095368	03/27/2021	Detector kit	0.4
Bohemia Elementary School	Bohemia Elementary	CR 4	5094968	03/27/2021	Detector kit	1.3
Bohemia Elementary School	Bohemia Elementary	CR 5	5095555	03/27/2021	Detector kit	0.5
Bohemia Elementary School	Bohemia Elementary	CR 6	5095557	03/27/2021	Detector kit	<0.3
Bohemia Elementary School	Bohemia Elementary	CR 7	5095502	03/27/2021	Detector kit	1.2
Bohemia Elementary School	Bohemia Elementary	CR 8	5095333	03/27/2021	Detector kit	0.7
Bohemia Elementary School	Bohemia Elementary	CR 9	5095560	03/27/2021	Detector kit	0.8
Bohemia Elementary School	Bohemia Elementary	CR 10	5113365	03/27/2021	Detector kit	1.5
Bohemia Elementary School	Bohemia Elementary	CR 11	5095511	03/27/2021	Detector kit	0.5
Bohemia Elementary School	Bohemia Elementary	CR 12	5102989	03/27/2021	Detector kit	1.1
Bohemia Elementary School	Bohemia Elementary	CR 13	5095364	03/27/2021	Detector kit	1.3
Bohemia Elementary School	Bohemia Elementary	CR 14	5095394	03/27/2021	Detector kit	1.3
Bohemia Elementary School	Bohemia Elementary	CR 15	5113375	03/27/2021	Detector kit	0.8
Bohemia Elementary School	Bohemia Elementary	LIB	5095222	03/27/2021	Detector kit	1.3
Bohemia Elementary School	Bohemia Elementary	LIB	5095359	03/27/2021	Detector kit	1.3
Bohemia Elementary School	Bohemia Elementary	LIB DUP	5102933	03/27/2021	Detector kit	0.9
Bohemia Elementary School	Bohemia Elementary	CR 16	5089437	03/27/2021	Detector kit	0.4
Bohemia Elementary School	Bohemia Elementary	CR 17	5095445	03/27/2021	Detector kit	0.4
Bohemia Elementary School	Bohemia Elementary	GYM	5095401	03/27/2021	Detector kit	0.7
Bohemia Elementary School	Bohemia Elementary	GYM	5094957	03/27/2021	Detector kit	0.5
Bohemia Elementary School	Bohemia Elementary	GYM	5095476	03/27/2021	Detector kit	0.7
Bohemia Elementary School	Bohemia Elementary	GYM DUP	5095262	03/27/2021	Detector kit	0.7
Bohemia Elementary School	Bohemia Elementary	MUSIC	5102915	03/27/2021	Detector kit	1.5
Bohemia Elementary School	Bohemia Elementary	MPR	5089984	03/27/2021	Detector kit	1.8
Bohemia Elementary School	Bohemia Elementary	MPR	5095327	03/27/2021	Detector kit	1.6
Bohemia Elementary School	Bohemia Elementary	CR 18	5102883	03/27/2021	Detector kit	<0.3
Bohemia Elementary School	Bohemia Elementary	CR 19	5089635	03/27/2021	Detector kit	<0.3

Bohemia Elementary School	Bohemia Elementary	CR 20	5095325	03/27/2021	Detector kit	3.5
Bohemia Elementary School	Bohemia Elementary	CR 21	5095353	03/27/2021	Detector kit	<0.3
Bohemia Elementary School	Bohemia Elementary	CR 22	5095371	03/27/2021	Detector kit	<0.3
Bohemia Elementary School	Bohemia Elementary	PRINCIPAL	5089447	03/27/2021	Detector kit	1.0
Bohemia Elementary School	Bohemia Elementary	COUNSELOR	5113458	03/27/2021	Detector kit	3.0
Bohemia Elementary School	Bohemia Elementary	OFFICE	5095544	03/27/2021	Detector kit	1.7
Bohemia Elementary School	Bohemia Elementary	CONF	5102875	03/27/2021	Detector kit	2.4
Bohemia Elementary School	Bohemia Elementary	NURSE	5102841	03/27/2021	Detector kit	1.1
Bohemia Elementary School	Bohemia Elementary	ADMIN	5102839	03/27/2021	Detector kit	0.9
Bohemia Elementary School	Bohemia Elementary	TEACHER AIDE	5089492	03/27/2021	Detector kit	0.5

☐ The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.

- 1 spike/blank test was conducted to ensure the integrity of the testing process and all spike/blank tests passed satisfactorily.

Radon Testing Results -SLSD Cottage Grove High School

Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Cottage Grove High School	Cottage Grove High	AUD DUP	5089481	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	MUSIC	5089923	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	MUSIC DUP	5089551	03/27/2021	Detector kit	<0.3
Cottage Grove High School	VTC	IT	5089546	03/27/2021	Detector kit	<0.3
Cottage Grove High School	VTC	IT DUP	5089599	03/27/2021	Detector kit	<0.3
Cottage Grove High School	VTC	DRAFTING	5089652	03/27/2021	Detector kit	<0.3
Cottage Grove High School	VTC	WOODSHOP	5102976	03/27/2021	Detector kit	<0.3
Cottage Grove High School	VTC	WOODSHOP	5089451	03/27/2021	Detector kit	<0.3
Cottage Grove High School	VTC	WOODSHOP DUP	5102698	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	116	5089918	03/27/2021	Detector kit	1.0
Cottage Grove High School	Cottage Grove High	118	5113534	03/27/2021	Detector kit	0.5
Cottage Grove High School	Cottage Grove High	120	5089576	03/27/2021	Detector kit	0.5
Cottage Grove High School	CG High Gym	WEIGHT	5089569	03/27/2021	Detector kit	0.5
Cottage Grove High School	CG High Gym	WEIGHT DUP	5089754	03/27/2021	Detector kit	0.4
Cottage Grove High School	CG High Gym	MAT	5090004	03/27/2021	Detector kit	<0.3
Cottage Grove High School	CG High Gym	MAT DUP	5102865	03/27/2021	Detector kit	<0.3
Cottage Grove High School	CG High Gym	MAIN GYM	5089638	03/27/2021	Detector kit	<0.3
Cottage Grove High School	CG High Gym	MAIN GYM	5089532	03/27/2021	Detector kit	0.7
Cottage Grove High School	CG High Gym	MAIN GYM	5102966	03/27/2021	Detector kit	<0.3
Cottage Grove High School	CG High Gym	MAIN GYM	5089516	03/27/2021	Detector kit	<0.3
Cottage Grove High School	CG High Gym	MAIN GYM	5089473	03/27/2021	Detector kit	<0.3
Cottage Grove High School	CG High Gym	MAIN GYM DUP	5102896	03/27/2021	Detector kit	0.4
Cottage Grove High School	CG High Gym	BIG GYM	5089672	03/27/2021	Detector kit	<0.3
Cottage Grove High School	CG High Gym	BIG GYM	5102882	03/27/2021	Detector kit	0.3
Cottage Grove High School	CG High Gym	BIG GYM	5102901	03/27/2021	Detector kit	<0.3
Cottage Grove High School	CG High Gym	BIG GYM	5089436	03/27/2021	Detector kit	<0.3
Cottage Grove High School	CG High Gym	BIG GYM DUP	5102912	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	113	5089455	03/27/2021	Detector kit	0.5

Cottage Grove High School	Cottage Grove High	STAFF	5089428	03/27/2021	Detector kit	0.4
Cottage Grove High School	Cottage Grove High	109	5089912	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	107	5089588	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	105	5089756	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	103	5102941	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	101	5089905	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	102	5089545	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	104	5102835	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	106	5089580	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	108	5102874	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	110	5102987	03/27/2021	Detector kit	0.8
Cottage Grove High School	Cottage Grove High	112	5089719	03/27/2021	Detector kit	1.0
Cottage Grove High School	Cottage Grove High	HEALTH CENTER	5102908	03/27/2021	Detector kit	0.8
Cottage Grove High School	Cottage Grove High	HEALTH CENTER	5089629	03/27/2021	Detector kit	0.6
Cottage Grove High School	Cottage Grove High	HEALTH CENTER	5089552	03/27/2021	Detector kit	0.6
Cottage Grove High School	Cottage Grove High	HEALTH CENTER	5102916	03/27/2021	Detector kit	0.7
Cottage Grove High School	Cottage Grove High	HEALTH CENTER	5102795	03/27/2021	Detector kit	0.6
Cottage Grove High School	Cottage Grove High	HEALTH CENTER	5089504	03/27/2021	Detector kit	0.6
Cottage Grove High School	Cottage Grove High	PRINCIPAL	5089524	03/27/2021	Detector kit	0.7
Cottage Grove High School	Cottage Grove High	COUNSELOR	5102984	03/27/2021	Detector kit	1.0
Cottage Grove High School	Cottage Grove High	ADMIN	5089670	03/27/2021	Detector kit	0.5
Cottage Grove High School	Cottage Grove High	AS. PRINCIPAL	5089579	03/27/2021	Detector kit	0.6
Cottage Grove High School	Cottage Grove High	WORK	5102811	03/27/2021	Detector kit	0.4
Cottage Grove High School	Cottage Grove High	CAFE	5089495	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	CAFE	5089471	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	CAFE	5089487	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	CAFE	5089738	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	CAFE	5089469	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	CAFE DUP	5089525	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	117	5089439	03/27/2021	Detector kit	1.1
Cottage Grove High School	Cottage Grove High	119	5102963	03/27/2021	Detector kit	0.7
Cottage Grove High School	Cottage Grove High	AUD	5089493	03/27/2021	Detector kit	0.7
Cottage Grove High School	Cottage Grove High	AUD	5089503	03/27/2021	Detector kit	<0.3
Cottage Grove High School	Cottage Grove High	AUD	5089549	03/27/2021	Detector kit	<0.3

Cottage Grove High School	Cottage Grove High	AUD DUP	5089998	03/27/2021	Detector kit	0.4
---------------------------	--------------------	---------	---------	------------	--------------	-----

- ☐ The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.
- 4 spike/blank tests were conducted to ensure the integrity of the testing process and all spike/blank tests passed satisfactorily.

Radon Testing Results -SLSD District Office

Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
District Office	District Office	BOARD	5113533	03/27/2021	Detector kit	0.4
District Office	District Office	BOARD DUP	5094806	03/27/2021	Detector kit	0.4
District Office	District Office	SECRETARIAL	5094856	03/27/2021	Detector kit	0.4
District Office	District Office	BUSINESS	5095549	03/27/2021	Detector kit	<0.3
District Office	District Office	ACCOUNTING	5094963	03/27/2021	Detector kit	<0.3
District Office	District Office	ACCOUNTING DUP	5094926	03/27/2021	Detector kit	0.3
District Office	District Office	CHILD ED	5095406	03/27/2021	Detector kit	0.6
District Office	District Office	RECEPTION	5094818	03/27/2021	Detector kit	0.7
District Office	District Office	PROGRAM	5095423	03/27/2021	Detector kit	0.6
District Office	District Office	OFFICE	5094827	03/27/2021	Detector kit	0.8
District Office	District Office	OFFICE	5095562	03/27/2021	Detector kit	0.8
District Office	District Office	OFFICE	5113546	03/27/2021	Detector kit	0.6
District Office	District Office	FOOD SERVICE	5094954	03/27/2021	Detector kit	0.5
District Office	District Office	FOOD SERVICE	5113486	03/27/2021	Detector kit	<0.3
District Office	District Office	FOOD SERVICE	5094918	03/27/2021	Detector kit	<0.3
District Office	District Office	FOOD DUP	5094836	03/27/2021	Detector kit	0.4

- ☐ The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.
- 1 spike/blank test was conducted to ensure the integrity of the testing process and all spike/blank tests passed satisfactorily.

Radon Testing Results -SLSD Dorena Elementary School

Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Dorena Elementary School	Dorena School	PRINCIPAL	5089846	03/28/2021	Detector kit	0.4
Dorena Elementary School	Dorena School	HEALTH	5089752	03/28/2021	Detector kit	0.6
Dorena Elementary School	Dorena School	MAIN OFF	5089533	03/28/2021	Detector kit	<0.3
Dorena Elementary School	Dorena School	CAFE	5089584	03/28/2021	Detector kit	0.8
Dorena Elementary School	Dorena School	CAFE	5089637	03/28/2021	Detector kit	0.8
Dorena Elementary School	Dorena School	CAFE DUP	5102923	03/28/2021	Detector kit	0.5
Dorena Elementary School	Dorena School	STAFF	5102910	03/28/2021	Detector kit	0.7
Dorena Elementary School	Gym	GYM	5089528	03/28/2021	Detector kit	1.9
Dorena Elementary School	Gym	GYM	5089506	03/28/2021	Detector kit	2.2
Dorena Elementary School	Gym	GYM	5089432	03/28/2021	Detector kit	2.0
Dorena Elementary School	Gym	GYM DUP	5102996	03/28/2021	Detector kit	2.2
Dorena Elementary School	Dorena School-Portable 3	2	5102980	03/28/2021	Detector kit	0.3
Dorena Elementary School	Dorena School-Portable 3	3	5089485	03/28/2021	Detector kit	0.4
Dorena Elementary School	Dorena School-Portable 2	4	5089543	03/28/2021	Detector kit	<0.3
Dorena Elementary School	Dorena School-Portable 2	5	5102821	03/28/2021	Detector kit	<0.3
Dorena Elementary School	Rm 5/Storage	6	5102868	03/28/2021	Detector kit	0.7
Dorena Elementary School	Rm 5/Storage	6 DUP	5089959	03/28/2021	Detector kit	0.7
Dorena Elementary School	Dorena School	COMPUTER	5090031	03/28/2021	Detector kit	<0.3
Dorena Elementary School	Dorena School	COMP DUP	5089522	03/28/2021	Detector kit	<0.3
Dorena Elementary School	Dorena School	LIB	5102860	03/28/2021	Detector kit	<0.3

- ▣ The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.
- 2 spike/blank tests were conducted to ensure the integrity of the testing process and all spike/blank tests passed satisfactorily.

Radon Testing Results -SLSD Early Learning Center

Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Early Learning Center	Early Learning Center	ADMIN OFF	5102822	03/28/2021	Detector kit	0.7
Early Learning Center	Early Learning Center	HEAD START	5113497	03/28/2021	Detector kit	0.9
Early Learning Center	Early Learning Center	WORK/STAFF	5102900	03/28/2021	Detector kit	0.9
Early Learning Center	Early Learning Center	203	5113498	03/28/2021	Detector kit	0.8
Early Learning Center	Early Learning Center	203 DUP	5089523	03/28/2021	Detector kit	0.4
Early Learning Center	Early Learning Center	202	5113488	03/28/2021	Detector kit	0.5
Early Learning Center	Early Learning Center	PRIMARY CONNECTION	5113371	03/28/2021	Detector kit	0.6

- ☐ The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.
- 1 spike/blank test was conducted to ensure the integrity of the testing process and all spike/blank tests passed satisfactorily.

Radon Testing Results -SLSD Harrison Elementary School

Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Harrison Elementary School	Harrison Elementary	NURSE	5095444	03/28/2021	Detector kit	0.6
Harrison Elementary School	Harrison Elementary	OFFICE	5095545	03/28/2021	Detector kit	0.4
Harrison Elementary School	Harrison Elementary	OFFICE	5095515	03/28/2021	Detector kit	<0.3
Harrison Elementary School	Harrison Elementary	PRINCIPAL	5095343	03/28/2021	Detector kit	<0.3
Harrison Elementary School	Harrison Elementary	ASSISTANT P.	5095522	03/28/2021	Detector kit	1.1
Harrison Elementary School	Harrison Elementary	CONF. ROOM	5094920	03/27/2021	Detector kit	<0.3
Harrison Elementary School	Harrison Elementary	STAFF LOUNGE	5095539	03/27/2021	Detector kit	1.2
Harrison Elementary School	Harrison Elementary	LIB	5094852	03/28/2021	Detector kit	<0.3
Harrison Elementary School	Harrison Elementary	LIB	5095381	03/27/2021	Detector kit	<0.3
Harrison Elementary School	Harrison Elementary	LIB DUP	5113425	03/27/2021	Detector kit	0.5
Harrison Elementary School	Harrison Elementary	MAKER SPACE	5095437	03/27/2021	Detector kit	0.8
Harrison Elementary School	Harrison Elementary	GROUP ROOM	5095536	03/27/2021	Detector kit	1.3
Harrison Elementary School	Harrison Elementary	RESOURCE 1	5094825	03/27/2021	Detector kit	<0.3
Harrison Elementary School	Harrison Elementary	111	5095495	03/27/2021	Detector kit	1.2
Harrison Elementary School	Harrison Elementary	112	5095289	03/28/2021	Detector kit	3.5
Harrison Elementary School	Harrison Elementary	113	5095543	03/28/2021	Detector kit	2.1
Harrison Elementary School	Harrison Elementary	114	5095475	03/28/2021	Detector kit	1.5
Harrison Elementary School	Harrison Elementary	101	5095434	03/28/2021	Detector kit	1.1
Harrison Elementary School	Harrison Elementary	102	5094947	03/28/2021	Detector kit	4.2
Harrison Elementary School	Harrison Elementary	103	5113402	03/28/2021	Detector kit	4.7
Harrison Elementary School	Harrison Elementary	104	5095520	03/28/2021	Detector kit	2.3
Harrison Elementary School	Harrison Elementary	121	5113396	03/28/2021	Detector kit	0.5
Harrison Elementary School	Harrison Elementary	122	5113487	03/28/2021	Detector kit	0.6
Harrison Elementary School	Harrison Elementary	123	5095350	03/28/2021	Detector kit	0.9
Harrison Elementary School	Harrison Elementary	124	5113526	03/28/2021	Detector kit	1.0
Harrison Elementary School	Harrison Elementary	OWL'S NEST	5113345	03/28/2021	Detector kit	1.1
Harrison Elementary School	Harrison Elementary	OWL DUP	5113500	03/28/2021	Detector kit	1.0
Harrison Elementary School	Harrison Elementary	MUSIC DUP	5113499	03/28/2021	Detector kit	0.4
Harrison Elementary School	Harrison Elementary	CAFE	5113485	03/28/2021	Detector kit	0.8
Harrison Elementary School	Harrison Elementary	CAFE	5095338	03/28/2021	Detector kit	1.0
Harrison Elementary School	Harrison Elementary	CAFE	5095375	03/28/2021	Detector kit	0.7
Harrison Elementary School	Harrison Elementary	CAFE DUP	5094886	03/28/2021	Detector kit	1.0
Harrison Elementary School	Harrison Elementary	GYM	5095559	03/28/2021	Detector kit	0.3

Harrison Elementary School	Harrison Elementary	GYM	5113356	03/28/2021	Detector kit	0.6
Harrison Elementary School	Harrison Elementary	GYM	5095521	03/28/2021	Detector kit	0.4
Harrison Elementary School	Harrison Elementary	GYM	5095446	03/28/2021	Detector kit	0.6
Harrison Elementary School	Harrison Elementary	GYM DUP	5095488	03/28/2021	Detector kit	0.4
Harrison Elementary School	Harrison Elementary	PE OFFICE	5094857	03/28/2021	Detector kit	0.4
Harrison Elementary School	Harrison Elementary	WORKROOM	5095498	03/28/2021	Detector kit	0.6
Harrison Elementary School	Harrison Elementary	102	5072398	06/14/2021	Retest	<0.3
Harrison Elementary School	Harrison Elementary	102 DUP	5071732	06/14/2021	Retest	0.4
Harrison Elementary School	Harrison Elementary	103	5071728	06/14/2021	Retest	0.4
Harrison Elementary School	Harrison Elementary	103 DUP	5071750	06/14/2021	Retest	<0.3

- ☐ The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.
- 1 spike/blank test was conducted to ensure the integrity of the testing process and all spike/blank tests passed satisfactorily.

Radon Testing Results -SLSD Lincoln Middle School

Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Lincoln Middle School	Classrooms	TECH	5102982	03/27/2021	Detector kit	0.7
Lincoln Middle School	Lincoln Middle	STAFF	5095558	03/27/2021	Detector kit	0.5
Lincoln Middle School	Lincoln Middle	STAFF	5095471	03/27/2021	Detector kit	<0.3
Lincoln Middle School	Lincoln Middle	OFFICE	5113452	03/27/2021	Detector kit	0.6
Lincoln Middle School	Lincoln Middle	OFFICE	5095411	03/27/2021	Detector kit	0.7
Lincoln Middle School	Lincoln Middle	OFFICE	5113578	03/27/2021	Detector kit	0.5
Lincoln Middle School	Lincoln Middle	OFFICE DUP	5095392	03/27/2021	Detector kit	0.9
Lincoln Middle School	Lincoln Middle	1	5102851	03/27/2021	Detector kit	2.1
Lincoln Middle School	Lincoln Middle	2	5094907	03/27/2021	Detector kit	2.6
Lincoln Middle School	Lincoln Middle	3	5113477	03/27/2021	Detector kit	2.6
Lincoln Middle School	Lincoln Middle	4	5095548	03/27/2021	Detector kit	2.2
Lincoln Middle School	Lincoln Middle	5	5095510	03/27/2021	Detector kit	2.2
Lincoln Middle School	Lincoln Middle	6	5094801	03/27/2021	Detector kit	2.5
Lincoln Middle School	Lincoln Middle	7	5113547	03/27/2021	Detector kit	2.1
Lincoln Middle School	Lincoln Middle	8	5094981	03/27/2021	Detector kit	2.9
Lincoln Middle School	Lincoln Middle	9	5095480	03/27/2021	Detector kit	2.3
Lincoln Middle School	Lincoln Middle	10	5095516	03/27/2021	Detector kit	2.4
Lincoln Middle School	Lincoln Middle	11	5095468	03/27/2021	Detector kit	2.1
Lincoln Middle School	Lincoln Middle	12	5113598	03/27/2021	Detector kit	2.7
Lincoln Middle School	Lincoln Middle	13	5094872	03/27/2021	Detector kit	0.8
Lincoln Middle School	Lincoln Middle	14	5102843	03/27/2021	Detector kit	0.6
Lincoln Middle School	Lincoln Middle	15	5102918	03/27/2021	Detector kit	0.6
Lincoln Middle School	Lincoln Middle	16	5102995	03/27/2021	Detector kit	0.7
Lincoln Middle School	Lincoln Middle	17	5089791	03/27/2021	Detector kit	0.7
Lincoln Middle School	Lincoln Middle	18	5102755	03/27/2021	Detector kit	0.4
Lincoln Middle School	Lincoln Middle	19	5102870	03/27/2021	Detector kit	0.5
Lincoln Middle School	Classrooms	CAFE	5089736	03/27/2021	Detector kit	0.7
Lincoln Middle School	Classrooms	CAFE	5090027	03/27/2021	Detector kit	<0.3
Lincoln Middle School	Classrooms	CAFE DUP	5102949	03/27/2021	Detector kit	0.4

Lincoln Middle School	Classrooms	21	5102943	03/27/2021	Detector kit	3.2
Lincoln Middle School	Classrooms	22	5102885	03/27/2021	Detector kit	3.8
Lincoln Middle School	Classrooms	31	5102818	03/27/2021	Detector kit	0.9
Lincoln Middle School	Classrooms	23	5102634	03/27/2021	Detector kit	2.7
Lincoln Middle School	Classrooms	24	5089624	03/27/2021	Detector kit	3.3
Lincoln Middle School	Classrooms	33	5089444	03/27/2021	Detector kit	0.6
Lincoln Middle School	Classrooms	25	5089468	03/27/2021	Detector kit	1.1
Lincoln Middle School	Classrooms	26	5102824	03/27/2021	Detector kit	1.5
Lincoln Middle School	Lincoln Middle	LIBRARY	5102829	03/27/2021	Detector kit	0.8
Lincoln Middle School	Classrooms	27	5089631	03/27/2021	Detector kit	1.0
Lincoln Middle School	Classrooms	28	5102819	03/27/2021	Detector kit	0.7
Lincoln Middle School	Lincoln Middle	LIBRARY	5102873	03/27/2021	Detector kit	1.1
Lincoln Middle School	Classrooms	29	5089452	03/27/2021	Detector kit	0.6
Lincoln Middle School	Lincoln Middle	34	5089477	03/27/2021	Detector kit	0.4
Lincoln Middle School	Lincoln Middle	36	5102702	03/27/2021	Detector kit	1.4
Lincoln Middle School	Lincoln Middle	37	5102812	03/27/2021	Detector kit	1.1
Lincoln Middle School	Lincoln Middle	38	5102977	03/27/2021	Detector kit	<0.3
Lincoln Middle School	Lincoln Middle	39	5102853	03/27/2021	Detector kit	1.1
Lincoln Middle School	Lincoln Middle	40	5089519	03/27/2021	Detector kit	0.4
Lincoln Middle School	Lincoln Middle	41	5102742	03/27/2021	Detector kit	<0.3
Lincoln Middle School	Lincoln Middle	41 DUP	5089534	03/27/2021	Detector kit	<0.3
Lincoln Middle School	Gym	LARGE GYM	5089653	03/27/2021	Detector kit	1.2
Lincoln Middle School	Gym	LARGE GYM	5102846	03/27/2021	Detector kit	1.2
Lincoln Middle School	Gym	LARGE GYM	5102637	03/27/2021	Detector kit	1.4
Lincoln Middle School	Gym	LARGE GYM	5102701	03/27/2021	Detector kit	1.2
Lincoln Middle School	Gym	LARGE GYM DUP	5089431	03/27/2021	Detector kit	1.5
Lincoln Middle School	Gym	LARGE GYM DUP	5102700	03/27/2021	Detector kit	1.1

- The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.
- 2 spike/blank tests were conducted to ensure the integrity of the testing process and all spike/blank tests passed satisfactorily.

Radon Testing Results -SLSD London Elementary School

Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
London Elementary School	London School	4	5113461	03/28/2021	Detector kit	2.5
London Elementary School	London School	5	5095492	03/28/2021	Detector kit	1.1
London Elementary School	London School	3	5095393	03/28/2021	Detector kit	2.0
London Elementary School	London School	2	5094913	03/28/2021	Detector kit	4.1
London Elementary School	London School	OFF	5095449	03/28/2021	Detector kit	0.3
London Elementary School	London School	PRINCIPAL	5113354	03/28/2021	Detector kit	0.9
London Elementary School	London School	FRONT DESK	5113424	03/28/2021	Detector kit	0.7
London Elementary School	London School	6	5094837	03/28/2021	Detector kit	1.4
London Elementary School	London School	GYM	5095413	03/28/2021	Detector kit	0.9
London Elementary School	London School	GYM	5095417	03/28/2021	Detector kit	0.5
London Elementary School	London School	GYM	5095464	03/28/2021	Detector kit	0.7
London Elementary School	London School	GYM DUP	5094854	03/28/2021	Detector kit	0.7
London Elementary School	London School	GYM DUP	5095319	03/28/2021	Detector kit	0.7
London Elementary School	London School	CAFE	5113590	03/28/2021	Detector kit	0.5
London Elementary School	London School	CAFE	5094874	03/28/2021	Detector kit	0.5
London Elementary School	London School	CAFE DUP	5113571	03/28/2021	Detector kit	0.5
London Elementary School	London School	1	5095357	03/28/2021	Detector kit	<0.3
London Elementary School	London School	1 DUP	5113592	03/28/2021	Detector kit	0.4
London Elementary School	London School	PORTABLE	5095561	03/28/2021	Detector kit	<0.3
London Elementary School	London School	PORTABLE	5095494	03/28/2021	Detector kit	<0.3
London Elementary School	London School	PORTABLE	5113558	03/28/2021	Detector kit	<0.3
London Elementary School	London School	STAFF	5094948	03/28/2021	Detector kit	0.4
London Elementary School	London School	SPECIAL ED	5095490	03/28/2021	Detector kit	<0.3
London Elementary School	Geo Dome	DOME	5089645	03/28/2021	Detector kit	2.6
London Elementary School	Geo Dome	DOME DUP	5094952	03/28/2021	Detector kit	2.7
London Elementary School	London School	NURSE	5095474	03/28/2021	Detector kit	0.7
London Elementary School	London School	2	5071718	06/14/2021	Retest	2.5

- ▣ The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.
- 1 spike/blank test was conducted to ensure the integrity of the testing process and all spike/blank tests passed satisfactorily.

Radon Testing Results -SLSD Maintenance Building/Bus Barn

Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Maintenance Building/Bus Barn	Maintenance Bldg	SUPERVISOR	5089510	03/27/2021	Detector kit	<0.3
Maintenance Building/Bus Barn	Bus Barn	AS. SUPER	5102981	03/27/2021	Detector kit	<0.3
Maintenance Building/Bus Barn	Bus Barn	BUS BARN	5089527	03/27/2021	Detector kit	<0.3
Maintenance Building/Bus Barn	Bus Barn	BUS BARN	5089555	03/27/2021	Detector kit	<0.3
Maintenance Building/Bus Barn	Bus Barn	BUS BARN	5089594	03/27/2021	Detector kit	<0.3
Maintenance Building/Bus Barn	Bus Barn	STAFF	5089582	03/27/2021	Detector kit	<0.3
Maintenance Building/Bus Barn	Bus Barn	STAFF DUP	5089430	03/27/2021	Detector kit	<0.3
Maintenance Building/Bus Barn	Maintenance Bldg	MAIN SUP	5102970	03/27/2021	Detector kit	8.1
Maintenance Building/Bus Barn	Maintenance Bldg	CHRIS	5089434	03/27/2021	Detector kit	4.0
Maintenance Building/Bus Barn	Maintenance Bldg	APRIL	5089662	03/27/2021	Detector kit	3.8
Maintenance Building/Bus Barn	Maintenance Bldg	WORK	5102862	03/27/2021	Detector kit	4.0
Maintenance Building/Bus Barn	Maintenance Bldg	WORK DUP	5102975	03/27/2021	Detector kit	4.0
Maintenance Building/Bus Barn	Maintenance Bldg	MAIN SUP	5071681	06/14/2021	Retest	3.7
Maintenance Building/Bus Barn	Maintenance Bldg	CHRIS	5071643	06/14/2021	Retest	2.2
Maintenance Building/Bus Barn	Maintenance Bldg	WORK	5072234	06/14/2021	Retest	3.3
Maintenance Building/Bus Barn	Maintenance Bldg	WORK DUP	2072578	06/14/2021	Retest	3.4

- ▣ The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.
- 2 spike/blank tests were conducted to ensure the integrity of the testing process and all spike/blank tests passed satisfactorily.

Radon Testing Results -SLSD Pool

Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Pool	Pool	OFFICE 102	5102986	03/27/2021	Detector kit	0.7
Pool	Pool	FRONT DESK	5089725	03/27/2021	Detector kit	0.5
Pool	Pool	POOL	5089656	03/27/2021	Detector kit	<0.3
Pool	Pool	POOL	5089610	03/27/2021	Detector kit	<0.3
Pool	Pool	POOL	5089427	03/27/2021	Detector kit	<0.3
Pool	Pool	POOL	5089992	03/27/2021	Detector kit	<0.3
Pool	Pool	POOL DUP	5102848	03/27/2021	Detector kit	<0.3

☐ The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.

- 1 spike/blank test was conducted to ensure the integrity of the testing process and all spike/blank tests passed satisfactorily.