

# Water Testing Results - Al Kennedy High School

## Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Outside Spigot, Outside Room 3	20870800-021OS	5/27/2021	ND
Room 3 Fountain	20870800-022DW	5/27/2021	ND
Room 3 Faucet	20870800-023CF	5/27/2021	ND
Room 4 Fountain	20870800-024DW	5/27/2021	ND
Room 4 Faucet	20870800-025CF	5/27/2021	ND
Boy's Bathroom Faucet, O/S Rm 4	20870800-026BF	5/27/2021	0.529
Girl's Bathroom Faucet, O/S Rm 4	20870800-027BF	5/27/2021	0.495
Outside Spigot, O/S Bathrooms	20870800-028OS	5/27/2021	0.472
Room 5 Fountain	20870800-030DW	5/27/2021	0.455
Room 5 Faucet	20870800-031CF	5/27/2021	0.427
Room 6 Faucet	20870800-032CF	5/27/2021	0.452
Room 7 Faucet	20870801- 029CF	5/27/2021	0.437
Outside Spigot, Outside Gym	20870802-001OS	Exempt/Disabled/Not Tested	Exempt/Disabled/Not Tested
Kitchen Faucet	20870802-002KF	5/26/2021	0.573
Kitchen Faucet, Next to Furnace Rm	20870802-003KF	5/26/2021	0.232
Inside Gym Fountain	20870802-004DW	5/26/2021	0.600
Bathroom Faucet, Boy's Shower	20870802-005BF	5/26/2021	0.554
Bathroom Faucet, Girl's Shower	20870802-006BF	5/26/2021	0.283
Custodian Bathroom Faucet	20870802-007BF	5/26/2021	0.210
Staff Workroom Faucet	20870802-008SF	5/26/2021	0.599
O/S Spigot, O/S Custodial Closet	20870802-009OS	5/26/2021	0.170
Health Room Faucet	20870803-019NS	5/27/2021	ND
Outside Spigot, Outside Office	20870803-020OS	5/27/2021	ND
Outside Spigot, Outside Rm 1	20870804-010OS	5/26/2021	ND
Room 2 Faucet	20870804-011CF	5/27/2021	ND
Room 2 Fountain	20870804-012DW	5/27/2021	ND
Room 7-B Faucet	20870804-013CF	5/27/2021	ND
Girl's Bath Faucet B/T Rm 1 & 2	20870804-014BF	5/27/2021	ND

Boy's Bath Faucet B/T Rm 1 & 2	20870804-015BF	5/27/2021	ND
Rm 1 Faucet, Next To Furnace Rm	20870804-016CF	5/27/2021	ND
Room 1 Faucet, North Wall	20870804-017CF	5/27/2021	ND
Fountain Outside Room 1	20870804-018DW	5/27/2021	ND

ND = Non Detect - Lead level is below the set detection limits of 2 ppb

# Water Testing Results - Bohemia Elementary School

## Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Room 1 Faucet	20870100-001CF	8/26/2021	5.16
Room 1 Fountain	20870100-002DW	8/26/2021	ND
Room 2 Faucet	20870100-003CF	8/26/2021	8.34
Room 2 Fountain	20870100-004DW	8/26/2021	ND
Room 3 Faucet	20870100-005CF	8/26/2021	ND
Room 3 Bathroom Faucet	20870100-006BF	8/26/2021	ND
Room 4 Faucet	20870100-007CF	8/26/2021	14.4
Room 4 Fountain	20870100-008DW	8/26/2021	ND
Room 5 Faucet	20870100-009CF	8/26/2021	ND
Room 5 Fountain	20870100-010DW	8/26/2021	ND
Room 6 Faucet	20870100-011CF	8/26/2021	ND
Room 6 Fountain	20870100-012DW	8/26/2021	ND
Room 7 Faucet	20870100-013CF	8/26/2021	ND
Room 7 Fountain	20870100-014DW	8/26/2021	ND
Room 8 Faucet	20870100-015CF	9/1/2021	ND
Room 8 Fountain	20870100-016DW	9/1/2021	ND
Room 9 Faucet	20870100-017CF	9/1/2021	ND
Room 9 Fountain	20870100-018DW	9/1/2021	ND
Room 10 Faucet	20870100-019CF	9/1/2021	ND
Room 10 Fountain	20870100-020DW	9/1/2021	4.21
Room 11 Faucet	20870100-021CF	9/1/2021	ND
Room 11 Fountain	20870100-022DW	9/1/2021	2.72
Room 12 Faucet	20870100-023CF	9/1/2021	ND
Room 12 Fountain	20870100-024DW	9/1/2021	ND
Room 13 Faucet	20870100-025CF	9/1/2021	ND
Room 13 Fountain	20870100-026DW	9/1/2021	3.63
Room 14 Faucet	20870100-027CF	9/1/2021	ND
Room 14 Fountain	20870100-028DW	9/1/2021	ND

Room 15 Faucet	20870100-029CF	9/1/2021	ND
Room 15 Fountain	20870100-030DW	9/1/2021	2.19
Room 16 Faucet	20870100-031CF	9/1/2021	ND
Room 16 Fountain	20870100-032DW	9/1/2021	ND
Room 17 Faucet	20870100-033CF	9/1/2021	ND
Room 17 Fountain	20870100-034DW	9/1/2021	ND
Room 18 Faucet	20870100-035CF	9/1/2021	ND
Room 18 Fountain	20870100-036DW	9/1/2021	ND
Room 19 Faucet	20870100-037CF	9/1/2021	ND
Room 19 Fountain	20870100-038DW	9/1/2021	ND
Room 20 Faucet	20870100-039CF	9/1/2021	ND
Room 20 Fountain	20870100-040DW	9/1/2021	ND
Room 21 Faucet	20870100-041CF	9/1/2021	ND
Room 21 Fountain	20870100-042DW	9/1/2021	ND
Room 22 Faucet	20870100-043CF	9/1/2021	2.28
Room 22 Fountain	20870100-044DW	9/1/2021	ND
Gym Fountain	20870100-045DW	9/1/2021	ND
Cafeteria Fountain	20870100-046DW	9/1/2021	ND
Room 20 Bathroom Faucet	20870100-047BF	9/1/2021	ND
Kitchen Dish Washing Station	20870100-048KF	9/1/2021	ND
Kitchen Handwashing Faucet	20870100-049KF	9/1/2021	ND
Kitchen Sanitation Faucet	20870100-050KF	9/1/2021	ND
Kitchen Produce Faucet	20870100-051KF	9/1/2021	ND
Kitchen Staff Bathroom Faucet	20870100-052BF	9/1/2021	ND
Middle SPED Classroom Faucet	20870100-053CF	9/1/2021	ND
Middle SPED Classroom Fountain	20870100-054DW	9/1/2021	2.39
North Boys B/R 1st Faucet	20870100-055BF	9/1/2021	ND
North Boys B/R 2nd Faucet	20870100-056BF	9/1/2021	ND
North Boys B/R 3rd Faucet	20870100-057BF	9/1/2021	ND
North Girls B/R 1st Faucet	20870100-058BF	9/1/2021	ND
North Girls B/R 2nd Faucet	20870100-059BF	9/1/2021	ND
North Girls B/R 3rd Faucet	20870100-060BF	9/1/2021	ND
West Boys B/R 1st Faucet	20870100-061BF	9/1/2021	ND
West Boys B/R 2nd Faucet	20870100-062BF	9/2/2021	ND

West Girls B/R 1st Faucet	20870100-063BF	9/2/2021	ND
West Girls B/R 2nd Faucet	20870100-064BF	9/2/2021	ND
South Boys B/R 1st Faucet	20870100-065BF	9/2/2021	ND
South Boys B/R 2nd Faucet	20870100-066BF	9/2/2021	ND
South Boys B/R 3rd Faucet	20870100-067BF	9/2/2021	ND
South Girls B/R 1st Faucet	20870100-068BF	9/2/2021	ND
South Girls B/R 2nd Faucet	20870100-069BF	9/2/2021	ND
South Girls B/R 3rd Faucet	20870100-070BF	9/2/2021	ND
Gym/Cafeteria Boys B/R Faucet	20870100-071BF	9/2/2021	ND
Gym/Cafeteria Girls B/R Faucet	20870100-072BF	9/3/2021	ND
Office, ADA Bathroom Faucet	20870100-073BF	9/3/2021	ND
Office, Womens Bathroom Faucet	20870100-074BF	9/3/2021	ND
Office, Mens Bathroom Faucet	20870100-075BF	9/3/2021	ND
Office, Nurses Handwash Faucet	20870100-076NS	9/3/2021	ND
Hall Drinking Fount O/S Rm 1	20870100-077DW	9/3/2021	ND
Hall Fount O/S Wildcat Rm	20870100-078DW	9/3/2021	ND
Hall Fount Between Rm 10 & 13	20870100-079DW	9/3/2021	ND
Hall Fount Between Room 15 & 16	20870100-080DW	9/3/2021	ND
Girls Locker Room Faucet	20870100-081BF	9/3/2021	ND
Girls Locker Room Shower Head #1	20870100-082SH	Exempt	
Girls Locker Room Shower Head #2	20870100-083SH	Exempt	
Girls Locker Room Shower Head #3	20870100-084SH	Exempt	
Cust. Floor Faucet, Gym Storage	20870100-085OT	Exempt	
Custodial Floor Faucet, Kitchen	20870100-086OT	Exempt	
Cust. Floor Fauc Near Staff Lounge	20870100-087OT	Exempt	
Cust. Floor Faucet Next to Room 7	20870100-088OT	Exempt	
Cust. Floor Fauc Between West B/R	20870100-089OT	Exempt	
Outside Spigot, East of Room 1	20870100-090OS	Exempt	
Outside Spigot, North of Room 5	20870100-091OS	Exempt	
Outside Spigot, Near Play Shed	20870101-092OS	Exempt	
Outside Spigot, West of Room 12	20870100-093OS	Exempt	
Outside Spigot, SW Corner of Gym	20870100-094OS	Exempt	
Outside Spigot, South of Kitchen	20870100-095OS	Exempt	
Outside Spigot, East of Room 18	20870100-096OS	Exempt	

Outside Spigot, East of Room 22	20870100-0970S	Exempt	
ND = Non Detect - Lead level is below the set detection limits			of 2 ppb

# Water Testing Results - Cottage Grove High School

## Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
O/S Spigot O/S Princ Office	20870700-001OS	Exempt	
O/S Spigot O/S Nurses Office	20870700-002OS	Exempt	
O/S Spigot B/T Rm 117 & 119	20870700-003OS	Exempt	
Principal's Office B/R Faucet	20870700-004BF	9/10/2021	ND
Office Copy Room Faucet	20870700-005OT	9/10/2021	ND
O/S Copy Rm Right B/R Faucet	20870700-006BF	9/10/2021	ND
O/S Copy Rm Left B/R Faucet	20870700-007BF	9/10/2021	ND
Copy Rm/Health 1st Rm on Rt Faucet	20870700-008OT	9/10/2021	ND
Copy Rm/Health 2nd Rm on RtFaucet	20870700-009OT	9/10/2021	ND
Copy Rm/Health End Of H/W B/R Faucet	20870700-010BF	9/10/2021	ND
Copy Rm/Health 3rd Rm on Left Faucet	20870700-011OT	9/10/2021	ND
Science Rm 101 Dedicated Eyewash Station	20870700-012OT	Exempt	
Science Rm 101 Shower	20870700-013SH	Exempt	
Science Rm 101 1st Fauc Rt	20870700-014CF	Exempt	
Science Rm 101 2nd Fauc Rt	20870700-015CF	Exempt	
Science Rm 101 3rd Fau Rt	20870700-016CF	Exempt	
Science Rm 101 4th Fauc Rt	20870700-017CF	Exempt	
Science Rm 101 5th Fauc Rt	20870700-018CF	Exempt	
Science Rm 101 6th Fauc Rt	20870700-019CF	Exempt	
Science Rm 101 7th Fauc Rt	20870700-020CF	Exempt	
Science Rm 101 8th Fauc Rt	20870700-021CF	Exempt	
Science Rm 101 9th Fauc Rt	20870700-022CF	Exempt	
Science Rm 102 Dedicated Eyewash Station	20870700-023OT	Exempt	
Science Rm 102 Shower	20870700-024SH	Exempt	
Science Rm 102 1st Fau Left	20870700-025CF	Exempt	
Science Rm 102 2nd Fau Left	20870700-026CF	Exempt	
Science Rm 102 3rd Fau Left	20870700-027CF	Exempt	
Science Rm 102 4th Fau Left	20870700-028CF	Exempt	

Science Rm 102 5th Fau Left	20870700-029CF	Exempt	
Science Rm 102 6th Fau Left	20870700-030CF	Exempt	
Science Rm 102 7th Fau Left	20870700-031CF	Exempt	
Science Rm 102 8th Fau Left	20870700-032CF	Exempt	
Science Rm 102 9th Fau Left	20870700-033CF	Exempt	
Sci Small Rm B/T 102 & 104 West Fau	20870700-034OT	9/10/2021	ND
Sci Small Rm B/T 102 & 104, East Faucet	20870700-035OT	9/10/2021	ND
Science Rm 103 Dedicated Eyewash Station	20870700-036OT	Exempt	
Science Rm 103 Shower	20870700-037SH	Exempt	
Science Rm 103 1st Fau Left	20870700-038CF	Exempt	
Science Rm 103 2nd Fau Left	20870700-039CF	Exempt	
Science Rm 103 3rd Fau Left	20870700-040CF	Exempt	
Science Rm 103 4th Fau Left	20870700-041CF	Exempt	
Science Rm 103 5th Fau Left	20870700-042CF	Exempt	
Science Rm 103 6th Fau Left	20870700-043CF	Exempt	
Science Rm 103 7th Fau Left	20870700-044CF	Exempt	
Science Rm 103 8th Fau Left	20870700-045CF	Exempt	
Science Rm 103 9th Fau Left	20870700-046CF	Exempt	
Science Rm 104 Dedicated Eyewash Station	20870700-047OT	Exempt	
Science Rm 104 Shower	20870700-048SH	Exempt	
Science Rm 104 1st Fau Rt	20870700-049CF	Exempt	
Science Rm 104 2nd Fau Rt	20870700-050CF	Exempt	
Science Rm 104 3rd Fau Rt	20870700-051CF	Exempt	
Science Rm 104 4th Fau Rt	20870700-052CF	Exempt	
Science Rm 104 5th Fau Rt	20870700-053CF	Exempt	
Science Rm 104 6th Fau Rt	20870700-054CF	Exempt	
Science Rm 104 7th Fau Rt	20870700-055CF	Exempt	
Science Rm 104 8th Fau Rt	20870700-056CF	Exempt	
Science Rm 104 9th Fau Rt	20870700-057CF	Exempt	
Science Rm 105 Dedicated Eyewash Station	20870700-058OT	Exempt	
Science Rm 105 Shower	20870700-059SH	Exempt	
Science Rm 105 1st Fau Rt	20870700-060CF	Exempt	
Science Rm 105 2nd Fau Rt	20870700-061CF	Exempt	
Science Rm 105 3rd Fau Rt	20870700-062CF	Exempt	



Science Rm 105 4th Fau Rt	20870700-063CF	Exempt	
Science Rm 105 5th Fau Rt	20870700-064CF	Exempt	
Science Rm 105 6th Fau Rt	20870700-065CF	Exempt	
Science Rm 105 7th Fau Rt	20870700-066CF	Exempt	
Science Rm 105 8th Fau Rt	20870700-067CF	Exempt	
Science Rm 105 9th Fau Rt	20870700-068CF	Exempt	
Science Rm 107 Dedicated Eyewash Station	20870700-069OT	Exempt	
Science Rm 107 Shower	20870700-070SH	Exempt	
Science Rm 107 1st Fau Left	20870700-071CF	Exempt	
Science Rm 107 2nd Fau Left	20870700-072CF	Exempt	
Science Rm 107 3rd Fau Left	20870700-073CF	Exempt	
Science Rm 107 4th Fau Left	20870700-074CF	Exempt	
Science Rm 107 5th Fau Left	20870700-075CF	Exempt	
Science Rm 107 6th Fau Left	20870700-076CF	Exempt	
Science Rm 107 7th Fau Left	20870700-077CF	Exempt	
Science Rm 107 8th Fau Left	20870700-078CF	Exempt	
Science Rm 107 9th Fau Left	20870700-079CF	Exempt	
End of S Main Hall Staff Fountain	20870700-080SF	9/10/2021	ND
End of S Main Hall, Science Fountain	20870700-081DW	9/10/2021	ND
Staff Lounge Bathroom Faucet	20870700-082BF	9/10/2021	ND
Staff Lounge Handwash Faucet	20870700-083SF	9/10/2021	ND
Main Hall/Sci Hall Girls B/R 1st E Fau	20870700-084BF	9/10/2021	ND
Main Hall/Sci Hall Girls B/R 2nd E Fau	20870700-085BF	9/10/2021	ND
Main Hall/Sci Hall Girls B/R 1st W Fau	20870700-086BF	9/12/2021	ND
Main Hall/Sci Hall Girls B/R 2nd W Fau	20870700-087BF	9/12/2021	ND
Main Hall/Sci Hall Boys B/R 1st E Fau	20870700-088BF	9/12/2021	ND
Main Hall/Sci Hall Boys B/R 2nd E Fau	20870700-089BF	9/12/2021	ND
Main Hall/Sci Hall Boys B/R 1st W Fau	20870700-090BF	9/12/2021	ND
Main Hall/Sci Hall Boys B/R 2nd W Fau	20870700-091BF	9/12/2021	ND
Room 110 North Wall Faucet	20870700-092CF	9/12/2021	ND
Room 110 1st Faucet on Left	20870700-093CF	9/12/2021	ND
Room 110 2nd Faucet on Left	20870700-094CF	9/12/2021	ND
Room 110, 3rd Faucet on Left	20870700-095CF	9/12/2021	ND
Room 112 First Faucet on Entering	20870700-096CF	9/12/2021	ND

Room 112 B/R 1st Faucet Right	20870700-097BF	9/12/2021	ND
Room 112 B/R 2nd Faucet Right	20870700-098BF	9/12/2021	ND
Room 112 B/R 3rd Faucet Right	20870700-099BF	9/12/2021	ND
Room 112 Fau Near Back Door	20870700-100CF	9/12/2021	ND
O/S Spigot O/S Rm 112 Back Door	20870700-101OS	Exempt	
Rm 114 Handwashing Faucet	20870700-102CF	9/12/2021	ND
Main Hall O/S Rm 114 South Fountain	20870700-103DW	9/12/2021	ND
Main Hall O/S Rm 114 North Fountain	20870700-104DW	9/12/2021	ND
O/S Spigot O/S Door of Commons	20870700-105OS	Exempt	
Commons Girls B/R 1st Fau Rt	20870700-106BF	9/12/2021	4.81
Commons Girls B/R 2nd Fau Rt	20870700-107BF	9/12/2021	4.37
Commons Girls B/R 3rd Fau Rt	20870700-108BF	9/12/2021	ND
Commons Girls B/R 4th Fau Rt	20870700-109BF	9/12/2021	ND
Commons Girls B/R 5th Fau Rt	20870700-110BF	9/12/2021	ND
Commons Girls B/R 6th Fau Rt	20870700-111BF	9/12/2021	ND
Commons Girls B/R 7th Fau Rt	20870700-112BF	9/12/2021	ND
Commons Boys B/R 1st Fau Left	20870700-113BF	9/12/2021	ND
Commons Boys B/R 2nd Fau Left	20870700-114BF	9/12/2021	ND
Commons Boys B/R 3rd Fau Left	20870700-115BF	9/12/2021	ND
Commons Boys B/R 4th Fau Left	20870700-116BF	9/12/2021	ND
Commons Boys B/R 5th Fau Left	20870700-117BF	9/12/2021	ND
Commons Boys B/R 6th Fau Left	20870700-118BF	9/12/2021	ND
Commons Boys B/R 7th Fau Left	20870700-119BF	9/12/2021	ND
Commons West Fountain	20870700-120DW	9/12/2021	ND
Commons East Fountain	20870700-121DW	9/12/2021	ND
Room 119 Dark Room Faucet	20870700-122CF	9/14/2021	10.2
End of Main N. Hall Near 119 S. Fountain	20870700-123DW	9/14/2021	5.67
Main Hall O/S Rm 119 N Fountain	20870700-124DW	9/14/2021	2.2
Music Hall ADA B/R Faucet	20870700-125BF	9/14/2021	ND
Music Hall Under Stairs B/R Faucet	20870700-126BF	9/14/2021	ND
Rm 123 1st Fau on Rt	20870700-127CF	9/14/2021	ND
Rm 123 2nd Fau on Rt	20870700-128CF	9/14/2021	ND
Rm 123 3rd Fau on Rt	20870700-129CF	9/14/2021	ND
O/S Spigot B/T Rm 123 & 124	20870700-144OS	Exempt	

O/S Spigot B/T Rm 121 & 122	20870700-145OS	Exempt	
O/S Spigot at Rm 124 Door	20870700-146OS	Exempt	
O/S Spigot Under Window Near Corner by Stairs	20870700-147OS	Exempt	
2nd Flr N. Wall Rt Fount (Facing Fountains)	20870700-148DW	9/14/2021	ND
2nd Flr N. Wall Left Fount (Facing Fount)	20870700-149DW	9/14/2021	2.95
2nd Flr ADA B/R Faucet	20870700-150BF	9/14/2021	ND
2nd Flr Next to ADA B/R Rt Fount (Facing Fountain)	20870700-151DW	9/14/2021	ND
2nd Flr Next to ADA B/R Left Fount (Facing Fount)	20870700-152DW	9/14/2021	ND
2nd Flr Girls B/R 1st Fau on Rt	20870700-153BF	9/15/2021	15.2
2nd Flr Girls B/R 2nd Fau Rt	20870700-154BF	9/15/2021	5.63
2nd Flr Girls B/R 3rd Fau Rt	20870700-155BF	9/15/2021	2.13
2nd Flr Girls B/R 4th Fau Rt	20870700-156BF	9/15/2021	2.3
2nd Flr Girls B/R 5th Fau Rt	20870700-157BF	9/15/2021	2.14
2nd Flr Girls B/R 6th Fau Rt	20870700-158BF	9/15/2021	28.4
2nd Flr Girls B/R 7th Fau Rt	20870700-159BF	9/15/2021	15.1
2nd Flr Boys B/R 1st Fau Left	20870700-160BF	9/15/2021	3.64
2nd Flr Boys B/R 2nd Fau Left	20870700-161BF	9/15/2021	ND
2nd Flr Boys B/R 3rd Fau Left	20870700-162BF	9/16/2021	ND
2nd Flr Boys B/R 4th Fau Left	20870700-163BF	9/16/2021	ND
2nd Flr Boys B/R 5th Fau Left	20870700-164BF	9/16/2021	ND
2nd Flr Boys B/R 6th Fau Left	20870700-165BF	9/16/2021	ND
2nd Flr Boys B/R 7th Fau Left	20870700-166BF	9/16/2021	ND
2nd Flr Library Office Faucet	20870700-167OT	9/16/2021	ND
2nd Flr Custodial Break Rm Faucet	20870700-168OT	9/16/2021	2.08
2nd Flr End of S. Hallway N. Fountain	20870700-169DW	9/16/2021	ND
2nd Flr End of S. Hallway S. Fount	20870700-170DW	9/16/2021	ND
Kitchen S. H/Washing Station Faucet	20870700-171KF	9/16/2021	ND
Kitchen Dish Wash Rm Rt Faucet	20870700-172KF	9/16/2021	ND
Kitchen Dish Wash Rm Left Faucet	20870700-173KF	9/16/2021	ND
Kitchen Dish Wash Rm Sprayer Faucet	20870700-174KF	9/16/2021	ND
Kitchen Bathroom Faucet	20870700-175BF	9/16/2021	ND
Kitchen W. H/Wash Station Faucet	20870700-176KF	9/16/2021	ND
Kitchen South Fountain	20870700-177DW	9/16/2021	ND
Kitchen North Fountain	20870700-178DW	9/16/2021	ND

Kitchen Ice Machine Faucet	20870700-179IM	9/16/2021	ND
Kitchen Produce West Faucet	20870700-180KF	9/16/2021	ND
Kitchen Produce East Faucet	20870700-181KF	9/19/2021	ND
Kitchen N. Wall H/Wash Faucet	20870700-182KF	9/19/2021	ND
Kitchen Rt Steamer Fau (Facing Steamer)	20870700-183KF	9/19/2021	ND
Kitchen Left Steamer Fau (Facing Steamer)	20870700-184KF	9/19/2021	ND
Kitchen Food Cauldron Faucet	20870700-185KF	9/19/2021	ND
O/S Spigot Near Kitchen Receiving	20870700-186OS	Exempt	
O/S Spigot W. Wall Science Hall	20870700-187OS	Exempt	
O/S Spigot B/T Rm 101 & 103	20870700-188OS	Exempt	
O/S Spigot B/T Rm 109 & Staff Rm	20870700-189OS	Exempt	
Cust. Sink B/T Rm 122 & 123	20870700-313OT	Exempt	
Cust. Sink Main Hall Near Commons	20870700-314OT	Exempt	
Cust. Sink Main Hall Near Elevator	20870700-315OT	Exempt	
Cust. Sink in Kitchen Area	20870700-316OT	Exempt	
Cust. Sink 2nd Flr Cust. Office	20870700-317OT	Exempt	
Cust. Sink 2nd Flr S. End of Hallway	20870700-318OT	Exempt	
O/S Spigot NW Wall Next to Fence	20870701-190OS	Exempt	
O/S Spigot Northeast Corner	20870701-191OS	Exempt	
O/S Spigot O/S Girls Locker Room	20870701-192OS	Exempt	
O/S Spigot O/S Boys Locker Room	20870701-193OS	Exempt	
O/S Spigot Southeast Corner	20870701-194OS	Exempt	
Boys Locker Rm N. B/R 1st Fau Left	20870701-195BF	9/19/2021	ND
Boys Locker Rm N. B/R 2nd Fau Left	20870701-196BF	9/19/2021	ND
Boys Locker Rm N. B/R 3rd Fau Left	20870701-197BF	9/19/2021	ND
Boys Locker Rm ADA Shower Near Cust. Closet	20870701-198SH	Exempt	
Boys Locker Rm N. Entry Rt Shower 1st Showerhead	20870701-199SH	Exempt	
Boys Locker Rm N. Entry Rt Shower 2nd Showerhead	20870701-200SH	Exempt	
Boys Locker Rm N. Entry Rt Shower 3rd Showerhead	20870701-201SH	Exempt	
Boys Locker Rm N. Entry Rt Shower 4th Showerhead	20870701-202SH	Exempt	
Boys Locker Rm N. Entry Rt Shower 5th Showerhead	20870701-203SH	Exempt	
Boys Locker Rm N. Entry Left Shower 1st Showerhead	20870701-204SH	Exempt	
Boys Locker Rm N. Entry Left Shower 2nd Showerhead	20870701-205SH	Exempt	
Boys Locker Rm N. Entry Left Shower 3rd Showerhead	20870701-206SH	Exempt	

Boys Locker Rm N. Entry Left Shower 4th Showerhead	20870701-207SH	Exempt	
Boys Locker Rm N. Entry Left Shower 5th Showerhead	20870701-208SH	Exempt	
Boys Locker Rm S. Entry Rt Shower 1st Showerhead	20870701-209SH	Exempt	
Boys Locker Rm S. Entry Rt Shower 2nd Showerhead	20870701-210SH	Exempt	
Boys Locker Rm S. Entry Rt Shower 3rd Showerhead	20870701-211SH	Exempt	
Boys Locker Rm S. Entry Rt Shower 4th Showerhead	20870701-212SH	Exempt	
Boys Locker Rm S. Entry Rt Shower 5th Showerhead	20870701-213SH	Exempt	
Boys Locker Rm S. Entry Left Shower 1st Showerhead	20870701-214SH	Exempt	
Boys Locker Rm S. Entry Left Shower 2nd Showerhead	20870701-215SH	Exempt	
Boys Locker Rm S. Entry Left Shower 3rd Showerhead	20870701-216SH	Exempt	
Boys Locker Rm S. Entry Left Shower 4th Showerhead	20870701-217SH	Exempt	
Boys Locker Rm S. Entry Left Shower 5th Showerhead	20870701-218SH	Exempt	
Boys Coaches Off B/R 1st Fau Right	20870701-219BF	9/19/2021	2.89
Boys Coaches Off B/R 2nd Fau Right	20870701-220BF	9/19/2021	2.46
Boys Coach Off B/R 1st Left ADA Shower	20870701-221SH	Exempt	
Boys Coach Off B/R 2nd Left Shower	20870701-222SH	Exempt	
Boys Coach Off B/R 3rd Left Shower	20870701-223SH	Exempt	
Boys Locker Rm S. B/R 1st Fauc Rt	20870701-224BF	9/19/2021	ND
Boys Locker Rm S. B/R 2nd Fau Rt	20870701-225BF	9/19/2021	ND
Boys Locker Rm S. B/R 3rd Fau Rt	20870701-226BF	9/19/2021	ND
Main E. Entrance H/Way 1st Fount Rt	20870701-227DW	9/19/2021	ND
Main E. Entrance H/Way 2nd Fount Rt	20870701-228DW	9/19/2021	ND
Main E. Entrance H/Way Mens B/R 1st Fau Left	20870701-229BF	9/19/2021	2.06
Main E. Entrance H/Way Mens B/R 2nd Fau Left	20870701-230BF	9/19/2021	ND
Main E. Entrance H/Way Mens B/R 3rd Fau Left	20870701-231BF	9/19/2021	3.33
Main E. Entrance H/Way Mens B/R 4th Fau Left	20870701-232BF	9/19/2021	3.38
Main E. Entrance H/Way Womens B/R 1st Fau Rt	20870701-233BF	9/19/2021	ND
Main E. Entrance H/Way Womens B/R 2nd Fau Rt	20870701-234BF	9/19/2021	ND
Main E. Entrance H/Way Womens B/R 3rd Fau Rt	20870701-235BF	9/19/2021	ND
Main E. Entrance H/Way Womens B/R 4th Fau Rt	20870701-236BF	9/19/2021	ND
Training Rm Ice Machine Faucet	20870701-237IM	9/19/2021	ND
Training Room Faucet	20870701-238OT	9/19/2021	ND
Training Room Soaking Tub Faucet	20870701-239OT	9/19/2021	ND
Main Hall Concession Faucet	20870701-240OT	9/21/2021	ND

Girls Locker Rm S. B/R 1st Fau Rt	20870701-241BF	9/21/2021	ND
Girls Locker Rm S. B/R 2nd Fau Rt	20870701-242BF	9/21/2021	ND
Girls Locker Rm S. B/R 3rd Fau Rt	20870701-243BF	9/21/2021	ND
Girls Locker Rm S. Entry Rt Shower 1st Showerhead	20870701-244SH	Exempt	
Girls Locker Rm S. Entry Rt Shower 2nd Showerhead	20870701-245SH	Exempt	
Girls Locker Rm S. Entry Rt Shower 3rd Showerhead	20870701-246SH	Exempt	
Girls Locker Rm S. Entry Rt Shower 4th Showerhead	20870701-247SH	Exempt	
Girls Locker Rm S. Entry Rt Shower 5th Showerhead	20870701-248SH	Exempt	
Girls Locker Rm S. Entry Rt Shower 6th Showerhead	20870701-249SH	Exempt	
Girls Locker Rm S. Entry Left Shower 1st Showerhead	20870701-250SH	Exempt	
Girls Locker Rm S. Entry Left Shower 2nd Showerhead	20870701-251SH	Exempt	
Girls Locker Rm S. Entry Left Shower 3rd Showerhead	20870701-252SH	Exempt	
Girls Locker Rm S. Entry Left Shower 4th Showerhead	20870701-253SH	Exempt	
Girls Locker Rm S. Entry Left Shower 5th Showerhead	20870701-254SH	Exempt	
Girls Locker Rm S. Entry Left Shower 6th Showerhead	20870701-255SH	Exempt	
Girls Locker Rm ADA South Shower	20870701-256SH	Exempt	
Girls Locker Rm N. Entry Rt Shower 1st Showerhead	20870701-257SH	Exempt	
Girls Locker Rm N. Entry Rt Shower 2nd Showerhead	20870701-258SH	Exempt	
Girls Locker Rm N. Entry Rt Shower 3rd Showerhead	20870701-259SH	Exempt	
Girls Locker Rm N. Entry Rt Shower 4th Showerhead	20870701-260SH	Exempt	
Girls Locker Rm N. Entry Rt Shower 5th Showerhead	20870701-261SH	Exempt	
Girls Locker Rm N. Entry Left Shower 1st Showerhead	20870701-262SH	Exempt	
Girls Locker Rm N. Entry Left Shower 2nd Showerhead	20870701-263SH	Exempt	
Girls Locker Rm N. Entry Left Shower 3rd Showerhead	20870701-264SH	Exempt	
Girls Locker Rm N. Entry Left Shower 4th Showerhead	20870701-265SH	Exempt	
Girls Locker Rm N. Entry Left Shower 5th Showerhead	20870701-266SH	Exempt	
Girls Locker Rm N. Entry Left Shower 6th Showerhead	20870701-267SH	Exempt	
Girls Locker Rm ADA North Shower	20870701-268SH	Exempt	
Girls Coach Off B/R 1st Fau Left	20870701-269BF	9/21/2021	4.02
Girls Coach Off B/R 2nd Fau Left	20870701-270BF	9/21/2021	4.94
Girls Coach Off B/R 1st Left ADA Shower	20870701-271SH	9/21/2021	5.01
Girls Coach Off B/R 2nd Left Shower	20870701-272SH	9/21/2021	3.66
Girls Coach Off B/R 3rd Left Shower	20870701-273SH	9/21/2021	3.47
Girls Locker Rm N. B/R 1st Fau Left	20870701-274BF	9/9/2021	14.5

Girls Locker Rm N. B/R 2nd Fau Left	20870701-275BF	9/21/2021	5.82
Girls Locker Rm N. B/R 3rd Fau Left	20870701-276BF	9/21/2021	5.16
Weight/Laundry Room Faucet	20870701-277OT	9/21/2021	ND
Weight Rm 1st Fountain on Left	20870701-278DW	9/21/2021	ND
Wt Rm Center Bottle Fill Station Left	20870701-279WB	9/21/2021	ND
Wt Rm Last Fountain on Left	20870701-280DW	9/21/2021	ND
Weight Room Bathroom Faucet	20870701-281BF	9/23/2021	ND
N. Hall, Near Girls Locker Rm Left Fountain	20870701-282DW	9/23/2021	ND
N. Hall, Near Girls Locker Rm Rt Fountain	20870701-283DW	9/23/2021	ND
N. Hall Rt Family/ADA B/R Faucet	20870701-284BF	9/23/2021	ND
N. Hall Rt Family/ADA B/R Shower	20870701-285SH	Exempt	
N. Hall Left Family/ADA B/R Faucet	20870701-286BF	9/23/2021	ND
N. Hall Left Family/ADA B/R Shower	20870701-287SH	Exempt	
Small Gym 1st Fountain on Left	20870701-288DW	9/23/2021	ND
Sm. Gym Center Bottle Fill Stn Left	20870701-289WB	9/23/2021	ND
Small Gym Last Fountain on Left	20870701-290DW	9/23/2021	ND
Main Gym 1st Fountain on Right	20870701-291DW	9/13/2021	3.39
Main Gym Center Bottle Fill Stn Rt	20870701-292WB	9/13/2021	3.31
Main Gym Last Fountain on Right	20870701-293DW	9/13/2021	3.09
W. Womens B/R N. Sink Left Faucet	20870701-294BF	9/13/2021	3.01
W. Womens B/R N. Sink Center Faucet	20870701-295BF	9/13/2021	2.66
W. Womens B/R N. Sink Right Faucet	20870701-296BF	9/13/2021	3.25
W. Womens B/R S. Sink Left Faucet	20870701-297BF	9/13/2021	ND
W. Womens B/R S. Sink Center Faucet	20870701-298BF	9/13/2021	ND
W. Womens B/R S. Sink Right Faucet	20870701-299BF	9/13/2021	ND
W. Mens B/R N. Sink Left Faucet	20870701-300BF	9/13/2021	ND
W. Mens B/R N. Sink Center Faucet	20870701-301BF	9/13/2021	ND
W. Mens B/R N. Sink Right Faucet	20870701-302BF	9/13/2021	ND
W. Mens B/R S. Sink Left Faucet	20870701-303BF	9/13/2021	2.59
W. Mens B/R S. Sink Center Faucet	20870701-304BF	9/13/2021	ND
W. Mens B/R S. Sink Right Faucet	20870701-305BF	9/13/2021	2.19
O/S Spigot Athletic Building SW	20870701-306OS	Exempt	
O/S Spigot Vocation Bldg East Side	20870702-130OS	Exempt	
Room 403 Faucet	20870702-131CF	9/14/2021	2.25

O/S Spigot Greenhouse Rt Wall Next to Door	20870702-132OS	Exempt	
O/S Spigot Garden Water Spigot	20870702-133OS	Exempt	
Vocational Bldg Boys B/R Rt Faucet	20870702-134BF	9/14/2021	2.01
Vocational Bldg Boys B/R Left Faucet	20870702-135BF	9/14/2021	4.08
Vocational Bldg Girls B/R Rt Faucet	20870702-136BF	9/14/2021	ND
Vocational Bldg Girls B/R Left Faucet	20870702-137BF	9/14/2021	4.83
Voc. Bldg Fount Corner of Hall & Rm 412	20870702-138DW	9/14/2021	ND
Room 412 Faucet	20870702-139CF	9/14/2021	ND
Outside Spigot by Room 411	20870702-140OS	Exempt	
O/S Spigot Opposite Covered Storage	20870702-141OS	Exempt	
Cust Sink Voc. Bldg Near Restrooms	20870702-319OT	Exempt	
Grandstand Concession Faucet	20870703-307OT	9/13/2021	ND
Grandstand Concession Tall Fountain	20870703-308DW	9/13/2021	ND
Grandstand Concession Short Fountain	20870703-309DW	9/13/2021	ND
O/S Spigot Grandstand E. Near Sandpit	20870703-310OS	Exempt	
O/S Spigot Grandstand W. Near Sandpit	20870703-311OS	Exempt	
O/S Spigot Community Garden O/S Track Fence	20870703-312OS	Exempt	
Maint Shed Handwashing Faucet	20870704-142OT	9/14/2021	7.46
Maint Shed Bathroom Faucet	20870704-143BF	9/14/2021	8.48
Retest			
2nd Flr Girls B/R 1st Fau on Rt	20870700-153BF	10/25/2021	ND
2nd Flr Girls B/R 6th Fau Rt	20870700-158BF	10/25/2021	ND
2nd Flr Girls B/R 7th Fau Rt	20870700-159BF	10/25/2021	ND

**ND = Non Detect - Lead level is below the set detection limits of 2 ppb**



# Water Testing Results - Daugherty Aquatic Center

## Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Boys Locker Room ADA Shower	20870001-001SH	Exempt	
Boys L/R Shower, Left aft ADA Show	20870001-002SH	Exempt	
Boys L/R 2nd Shower on Right	20870001-003SH	Exempt	
Boys L/R 1st Shower on Right	20870001-004SH	Exempt	
Boys L/R Bathroom Faucet on Left	20870001-005BF	10/25/2021	ND
Boys L/R Bathroom Faucet on Rt	20870001-006BF	10/25/2021	ND
Drinking Fountain	20870001-007DW	10/25/2021	ND
Drinking Fountain/ Bottle Filler	20870001-008WB	10/25/2021	ND
Hose Bib Next to Drinking Fount	20870001-009OT	Exempt	
Hose Bib on Wall Opp Drink Fount	20870001-010OT	Exempt	
Girls Locker Room ADA Shower	20870001-011SH	Exempt	
Girls L/R 1st Shower aft ADA Show	20870001-012SH	Exempt	
Girls L/R 2nd Shower aft ADA Show	20870001-013SH	Exempt	
Girls L/R 3rd Shower aft ADA Show	20870001-014SH	Exempt	
Girls L/R 4th Shower aft ADA Show	20870001-015SH	Exempt	
Girls L/R Bathroom Faucet on Left	20870001-016BF	10/25/2021	ND
Girls L/R Bathroom Faucet on Rt	20870001-017BF	10/25/2021	ND
Custodial Floor Faucet, Laundry/St	20870001-018OT	Exempt	
Family Shower Room Shower	20870001-019SH	Exempt	
Family Shower Rm Bath Faucet	20870001-020BF	10/25/2021	ND

ND = Non Detect - Lead level is below the set detection limits of 2 ppb

# Water Testing Results - District Office

## Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Faucet, Staff Kitchen, Personnel Side	20870000-001KF	5/26/2021	0.351
Faucet, Girl's Bath Next to Board Rm	20870000-002BF	5/26/2021	2.55
Faucet, Boy's Bath Next to Board Rm	20870000-003BF	5/26/2021	2.59
Faucet, Board Room	20870000-004OT	5/26/2021	2.81
Drinking Fountain, Hallway	20870000-005DW	5/26/2021	6.47
Faucet, Girl's Bath Next to Food Svc	20870000-006BF	5/26/2021	0.116
Faucet, Boy's Bath Next to Food Svc	20870000-007BF	5/26/2021	ND
Faucet, Staff Kitchen, Food Svc Side	20870000-008KF	5/26/2021	2.42
Shower, Girls Bath, Food Svc Side	20870000-009SH	Exempt	
Outside Spigot, East of Front Entrance	20870000-010OS	Exempt	
Outside Spigot, East Side of Bldg	20870000-011OS	Exempt	
Outside Spigot, West Side of Bldg	20870000-012OS	Exempt	

**ND = Non Detect - Lead level is below the set detection limits of 2 ppb**

# Water Testing Results - Dorena Elementary School

## Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Room 1 Faucet	20870200-012CF	5/26/2021	ND
Outside Spigot O/S Boiler Room	20870200-013OS	5/26/2021	ND
Girls Bathroom Left Faucet	20870200-014BF	5/26/2021	0.117
Girls Bathroom Center Faucet	20870200-015BF	5/26/2021	ND
Girls Bathroom Right Faucet	20870200-016BF	5/26/2021	ND
Boys Bathroom Left Faucet	20870200-017BF	5/26/2021	0.716
Boys Bathroom Center Faucet	20870200-018BF	5/26/2021	0.503
Boys Bathroom Right Faucet	20870200-019BF	5/26/2021	0.542
Hall Fountain Between Bathrooms	20870200-020DW	5/26/2021	0.560
Staff Bathroom Faucet	20870200-021BF	5/26/2021	1.38
Staffroom Faucet	20870200-022SF	5/26/2021	8.08
Staffroom Fountain	20870200-023DW	5/26/2021	3.43
Room 2 Faucet	20870200-024CF	5/26/2021	2.65
Outside Spigot O/S Principals Off	20870200-034OS	5/26/2021	0.298
Office Bathroom Faucet	20870200-035BF	5/26/2021	0.247
Kitchen Faucet	20870200-036KF	5/26/2021	0.202
Storeroom Faucet	20870200-037OT	5/26/2021	0.104
Outside Spigot O/S Kitchen	20870200-038OS	5/26/2021	0.110
Gym Boys Bathroom Left Faucet	20870201-002BF	5/26/2021	2.77
Gym Boys Bathroom Right Faucet	20870201-003BF	5/26/2021	3.62
Gym Girls Bathroom Faucet	20870201-004BF	5/26/2021	0.294
Fountain Inside Gym	20870201-005DW	5/26/2021	11.8
Fountain Outside Gym	20870201-006DW	5/14/2021	46.7
Room 3 Bathroom Faucet	20870202-007BF	5/26/2021	1.68
Room 3 Fountain	20870202-008DW	5/26/2021	1.82
Outside Spigot O/S Storage Bldg	20870203-001OS	5/26/2021	2.36
Room 10 Bathroom Faucet	20870204-009BF	5/26/2021	0.341
Room 10 Faucet	20870204-010CF	5/26/2021	0.269

Room 10 Fountain	20870204-011DW	5/26/2021	0.397
Foom 4 Faucet	20870205-025CF	5/26/2021	1.10
Room 4 Fountain	20870205-026DW	5/26/2021	0.812
Room 5 Faucet	20870205-027CF	5/26/2021	1.25
Room 5 Fountain	20870205-028DW	5/26/2021	0.126
Outside Spigot O/S Room 5	20870205-029OS	5/26/2021	0.153
Room 6 Faucet	20870206-030CF	5/26/2021	0.137
Room 6 Fountain	20870206-031DW	5/26/2021	0.122
Room 7 Faucet	20870206-032CF	5/26/2021	0.114
Room 7 Fountain	20870206-033DW	5/26/2021	0.114
Retest			
Fountain Outside Gym	20870201-006DW		<b>Fixture Disabled</b>

ND = Non Detect - Lead level is below the set detection limits of 2 ppb

## Water Testing Results - Early Learning Center

### Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Staff Room	20870002-001SF	10/25/2021	ND
Restroom #1, Main Hall	20870002-002BF	10/25/2021	ND
Restroom #2, Main Hall	20870002-003BF	10/25/2021	ND
Custodial Closet Sink	20870002-004OT	Exempt	
Kitchen Faucet	20870002-005KF	10/25/2021	ND
First Classroom on Right Faucet	20870002-006CF	10/25/2021	ND
First Classroom on Right Fountain	20870002-007DW	10/25/2021	ND
Second Classroom on Right Faucet	20870002-008CF	10/25/2021	ND
Second Classroom on Right Fountain	20870002-009DW	10/25/2021	ND
Kids R/R Faucet #1 Starting @ Entrance	20870002-010BF	10/25/2021	ND
Kids Restroom Faucet #2	20870002-011BF	10/25/2021	ND
Kids Restroom Faucet #3	20870002-012BF	10/25/2021	ND
Kids Restroom Faucet #4	20870002-013BF	10/25/2021	ND
Classroom on Left Faucet	20870002-014CF	10/25/2021	ND
Classroom on Left Fountain	20870002-015DW	10/25/2021	ND
Outside Spigot	20870002-016OS	Exempt	

**ND = Non Detect - Lead level is below the set detection limits of 2 ppb**

# Water Testing Results - Harrison Elementary School

## Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Nurses Office Bathroom Shower	20870300-001SH	Exempt	
Nurses Office Bathroom Faucet	20870300-002BF	9/5/2021	ND
Nurses Office Handwash Faucet	20870300-003NS	9/5/2021	ND
Main Office Mother's Rm Faucet	20870300-004OT	9/5/2021	ND
Main Office Staff Break Rm Faucet	20870300-005SF	9/5/2021	ND
Main Off N. Staff Bathroom Faucet	20870300-006BF	9/5/2021	ND
Main Off S. Staff B/R Shower	20870300-007SH	Exempt	
Main Off S. Staff Bathroom Faucet	20870300-008BF	9/5/2021	ND
Main Hall Boys B/R Faucet 1st	20870300-009BF	9/5/2021	ND
Main Hall Boys B/R Faucet 2nd	20870300-010BF	9/5/2021	ND
Main Hall Boys B/R Faucet 3rd	20870300-011BF	9/5/2021	ND
Main Hall Girls B/R Faucet 1st	20870300-012BF	9/5/2021	ND
Main Hall Girls B/R Faucet 2nd	20870300-013BF	9/5/2021	ND
Main Hall Girls B/R Faucet 3rd	20870300-014BF	9/5/2021	ND
Main Hall W/B Fill Station/Fount	20870300-015WB	9/5/2021	ND
Main Hall Fountain	20870300-016DW	9/5/2021	ND
Library Librarian Faucet	20870300-017CF	9/5/2021	ND
Library Maker Space Faucet	20870300-018CF	9/5/2021	ND
Cafeteria Faucet	20870300-019OT	9/5/2021	ND
Kitchen Dishwashing Faucet	20870300-020KF	9/5/2021	ND
Kitchen Sanitation Faucet	20870300-021KF	9/5/2021	ND
Kitchen H/W Faucet Near San Sink	20870300-022KF	9/5/2021	ND
Kitchen Produce Faucet	20870300-023KF	9/5/2021	ND
Kitchen H/W Faucet Near Produce Sink	20870300-024KF	9/5/2021	ND
Receiving Custodial Faucet	20870300-025OT	Exempt	
Receiving Bathroom Faucet	20870300-026BF	9/5/2021	ND
Music Room Faucet	20870300-027CF	9/5/2021	ND
Music Room Fountain	20870300-028DW	9/5/2021	ND

1st Floor Owl's Nest Faucet	20870300-029CF	9/5/2021	ND
1st Floor Owl's Nest Fountain	20870300030DW	9/5/2021	ND
1st Floor Owl's Nest B/R Faucet	20870300-031BF	9/5/2021	ND
1st Grade Pod Commons N. Faucet	20870300-032CF	9/5/2021	ND
1st Grade Pod Commons N. Fount	20870300-033DW	9/5/2021	ND
1st Grade Pod Commons S. Faucet	20870300-034CF	9/5/2021	ND
1st Grade Pod Commons S. Fount.	20870300-035DW	9/5/2021	ND
Room 111 Faucet	20870300-036CF	9/5/2021	ND
Room 111 Fountain	20870300-037DW	9/5/2021	ND
Room 112 Faucet	20870300-038CF	9/5/2021	ND
Room 112 Fountain	20870300-039DW	9/5/2021	ND
Room 113 Faucet	20870300-040CF	9/5/2021	ND
Room 113 Fountain	20870300-041DW	9/5/2021	ND
Room 114 Faucet	20870300-042CF	9/5/2021	ND
Room 114 Fountain	20870300-043DW	9/5/2021	ND
1st Grade Pod Boys B/R 1st Faucet	20870300-044BF	9/5/2021	ND
1st Grade Pod Boys B/R 2nd Faucet	20870300-045BF	9/5/2021	ND
1st Grade Pod Boys B/R 3rd Faucet	20870300-046BF	9/5/2021	ND
1st Grade Pod Girls B/R 1st Faucet	20870300-047BF	9/5/2021	ND
1st Grade Pod Girls B/R 2nd Faucet	20870300-048BF	9/5/2021	ND
1st Grade Pod Girls B/R 3rd Faucet	20870300-049BF	9/5/2021	ND
1st Grade Pod Staff B/R Faucet Main Hall	20870300-050BF	9/5/2021	ND
2nd Grade Pod Commons N. Faucet	20870300-051CF	9/5/2021	ND
2nd Grade Pod Commons N. Fount	20870300-052DW	9/5/2021	ND
2nd Grade Pod Commons S. Faucet	20870300-053CF	9/5/2021	ND
2nd Grade Pod Commons S. Fount	20870300-054DW	9/5/2021	ND
Room 121 Faucet	20870300-055CF	9/5/2021	ND
Room 121 Fountain	20870300-056DW	9/5/2021	ND
Room 122 Faucet	20870300-057CF	9/5/2021	ND
Room 122 Fountain	20870300-058DW	9/5/2021	ND
Room 123 Faucet	20870300-059CF	9/5/2021	ND
Room 123 Fountain	20870300-060DW	9/5/2021	ND
Room 124 Faucet	20870300-061CF	9/5/2021	ND
Room 124 Fountain	20870300-062DW	9/5/2021	ND

2nd Grade Pod Boys B/R 1st Faucet	20870300-063BF	9/5/2021	ND
2nd Grade Pod Boys B/R 2nd Faucet	20870300-064BF	9/5/2021	ND
2nd Grade Pod Boys BR 3rd Faucet	20870300-065BF	9/5/2021	ND
2nd Grade Pod Girls B/R 1st Faucet	20870300-066BF	9/5/2021	ND
2nd Grade Pod Girls B/R 2nd Faucet	20870300-067BF	9/5/2021	ND
2nd Grade Pod Girls B/R 3rd Faucet	20870300-068BF	9/5/2021	ND
2nd Grade Pod Staff B/R Faucet Main Hall	20870300-069BF	9/5/2021	ND
Kinder Pod Commons E. Faucet	20870300-070CF	9/5/2021	ND
Kinder Pod Commons E. Fountain	20870300-071DW	9/5/2021	ND
Kinder Pod Commons W. Faucet	20870300-072CF	9/5/2021	ND
Kinder Pod Commons W. Fountain	20870300-073DW	9/6/2021	ND
Room 101 Faucet	20870300-074CF	9/6/2021	ND
Room 101 Fountain	20870300-075DW	9/6/2021	ND
Room 102 Faucet	20870300-076CF	9/6/2021	ND
Room 102 Fountain	20870300-077DW	9/6/2021	ND
Room 103 Faucet	20870300-078CF	9/6/2021	ND
Room 103 Fountain	20870300-079DW	9/6/2021	ND
Room 104 Faucet	20870300-080CF	9/6/2021	ND
Room 104 Fountain	20870300-081DW	9/6/2021	ND
Kinder Pod Boys B/R 1st Faucet	20870300-082BF	9/6/2021	ND
Kinder Pod Boys B/R 2nd Faucet	20870300-083BF	9/6/2021	ND
Kinder Pod Boys B/R 3rd Faucet	20870300-084BF	9/6/2021	ND
Kinder Pod Girls B/R 1st Faucet	20870300-085BF	9/6/2021	ND
Kinder Pod Girls B/R 2nd Faucet	20870300-086BF	9/6/2021	ND
Kinder Pod Girls B/R 3rd Faucet	20870300-087BF	9/6/2021	ND
Kinder Pod Staff B/R Faucet Main Hall	20870300-088BF	9/6/2021	ND
5th Grade Pod Commons E. Faucet	20870300-089CF	9/6/2021	ND
5th Grade Pod Commons E. Fount	20870300-090DW	9/6/2021	ND
5th Grade Pod Commons W. Faucet	20870300-091CF	9/6/2021	ND
5th Grade Pod Commons W. Fountain	20870300-092DW	9/6/2021	ND
Room 251 Faucet	20870300-093CF	9/6/2021	ND
Room 251 Fountain	20870300-094DW	9/6/2021	ND
Room 252 Faucet	20870300-095CF	9/6/2021	ND
Room 252 Fountain	20870300-096DW	9/6/2021	ND



Room 253 Faucet	20870300-097CF	9/6/2021	ND
Room 253 Fountain	20870300-098DW	9/6/2021	ND
Room 254 Faucet	20870300-099CF	9/6/2021	ND
Room 254 Fountain	20870300-100DW	9/6/2021	ND
5th Grade Pod Boys B/R 1st Faucet	20870300-101BF	9/6/2021	ND
5th Grade Pod Boys B/R 2nd Faucet	20870300-102BF	9/6/2021	ND
5th Grade Pod Boys B/R 3rd Faucet	20870300-103BF	9/6/2021	ND
5th Grade Pod Girls B/R 1st Faucet	20870300-104BF	9/3/2021	ND
5th Grade Pod Girls B/R 2nd Faucet	20870300-105BF	9/3/2021	ND
5th Grade Pod Girls B/R 3rd Faucet	20870300-106BF	9/3/2021	ND
5th Grade Pod Staff B/R Faucet Main Hall	20870300-107BF	9/3/2021	ND
4th Grade Pod Commons N. Faucet	20870300-108CF	9/3/2021	ND
4th Grade Pod Commons N. Fountain	20870300-109DW	9/3/2021	ND
4th Grade Pod Commons S. Faucet	20870300-110CF	9/3/2021	ND
4th Grade Pod Commons S. Fountain	20870300-111DW	9/3/2021	ND
Room 241 Faucet	20870300-112CF	9/3/2021	ND
Room 241 Fountain	20870300-113DW	9/3/2021	ND
Room 242 Faucet	20870300-114CF	9/4/2021	ND
Room 242 Fountain	20870300-115DW	9/4/2021	ND
Room 243 Faucet	20870300-116CF	9/4/2021	ND
Room 243 Fountain	20870300-117DW	9/4/2021	ND
Room 244 Faucet	20870300-118CF	9/4/2021	ND
Room 244 Fountain	20870300-119DW	9/4/2021	ND
4th Grade Pod Boys B/R 1st Faucet	20870300-120BF	9/4/2021	ND
4th Grade Pod Boys B/R 2nd Faucet	20870300-121BF	9/4/2021	ND
4th Grade Pod Boys B/R 3rd Faucet	20870300-122BF	9/4/2021	ND
4th Grade Pod Girls B/R 1st Faucet	20870300-123BF	9/4/2021	ND
4th Grade Pod Girls B/R 2nd Faucet	20870300-124BF	9/4/2021	ND
4th Grade Pod Girls B/R 3rd Faucet	20870300-125BF	9/4/2021	ND
4th Grade Pod Staff B/R Faucet Main Hall	20870300-126BF	9/4/2021	ND
3rd Grade Pod Commons N. Faucet	20870300-127CF	9/4/2021	ND
3rd Grade Pod Commons N. Fountain	20870300-128DW	9/4/2021	ND
3rd Grade Pod Commons S. Faucet	20870300-129CF	9/4/2021	ND
3rd Grade Pod Commons S. Fountain	20870300-130DW	9/4/2021	ND

Room 231 Faucet	20870300-131CF	9/4/2021	ND
Room 231 Fountain	20870300-132DW	9/4/2021	ND
Room 232 Faucet	20870300-133CF	9/4/2021	ND
Room 232 Fountain	20870300-134DW	9/4/2021	ND
Room 233 Faucet	20870300-135CF	9/4/2021	ND
Room 233 Fountain	20870300-136DW	9/4/2021	ND
Room 234 Faucet	20870300-137CF	9/4/2021	ND
Room 234 Fountain	20870300-138DW	9/4/2021	ND
3rd Grade Pod Boys B/R 1st Faucet	20870300-139BF	9/4/2021	ND
3rd Grade Pod Boys B/R 2nd Faucet	20870300-140BF	9/4/2021	ND
3rd Grade Pod Boys B/R 3rd Faucet	20870300-141BF	9/4/2021	ND
3rd Grade Pod Girls B/R 1st Faucet	20870300-142BF	9/4/2021	ND
3rd Grade Pod Girls B/R 2nd Faucet	20870300-143BF	9/4/2021	ND
3rd Grade Pod Girls B/R 3rd Faucet	20870300-144BF	9/5/2021	ND
3rd Grade Pod Staff B/R Faucet Main Hall	20870300-145BF	9/5/2021	ND
2nd Floor Owl's Nest Faucet	20870300-146CF	9/5/2021	ND
2nd Floor Owl's Nest Fountain	20870300-147DW	9/5/2021	ND
2nd Floor Owl's Nest B/R Faucet	20870300-148BF	9/5/2021	ND
Project Studio Faucet	20870300-149CF	9/5/2021	ND
Project Studio Kitchen Faucet	20870300-150KF	9/5/2021	ND
Receiving Outside Spigot	20870300-151OS	Exempt	
Cafeteria Outside Spigot	20870300-152OS	Exempt	
Owl's Nest Outside Spigot	20870300-153OS	Exempt	
Garden Area Outside Spigot	20870300-154OS	Exempt	
West Exit Under Window O/S Spigot	20870300-155OS	Exempt	

ND = Non Detect - Lead level is below the set detection limits of 2 ppb

# Water Testing Results - Lincoln Middle School

## Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
3rd Hall Boy's Bathroom Faucet	20870600-153BF	9/26/2021	ND
3rd Hall Boy's Handicap B/R Fau	20870600-154BF	9/26/2021	ND
3rd Hall Girl's Bathroom Faucet	20870600-155BF	9/26/2021	ND
3rd Hall Girl's Handicap B/R Fau	20870600-156BF	9/26/2021	2.88
First 3rd Hall Fountain	20870600-157DW	9/26/2021	ND
Second 3rd Hall Fountain	20870600-158DW	9/26/2021	ND
2nd Hall Boy's Bathroom Faucet	20870600-159BF	9/26/2021	ND
2nd Hall Girl's Bathroom Faucet	20870600-160BF	9/26/2021	ND
First 2nd Hall Fountain	20870600-161DW	9/26/2021	ND
Second 2nd Hall Fountain	20870600-162DW	9/26/2021	ND
1st Hall Boy's Bathroom Faucet	20870600-163BF	9/26/2021	ND
1st Hall Girl's Bathroom Faucet	20870600-164BF	9/26/2021	ND
First 1st Hall Fountain	20870600-165DW	9/26/2021	ND
Second 1st Hall Fountain	20870600-166DW	9/26/2021	ND
O/S Spigot Between Rm 1 and 3	20870600-173OS	Exempt	
O/S Spigot Breezeway O/S Rm 5	20870600-174OS	Exempt	
O/S Spigot Between Rm 7 and 9	20870600-175OS	Exempt	
O/S Spigot Breezeway O/S Rm 11	20870600-176OS	Exempt	
O/S Spigot Between Rm 17 and 19	20870600-177OS	Exempt	
O/S Spigot Between Rm 16 and 18	20870600-178OS	Exempt	
O/S Spigot, O/S 3rd Hall Bathrooms	20870600-179OS	Exempt	
Girls Locker Rm S. Sh Tower 1, #1	20870601-001SH	Exempt	
Girls Locker Rm S. Sh Tower 1, #2	20870601-002SH	Exempt	
Girls Locker Rm S. Sh Tower 1, #3	20870601-003SH	Exempt	
Girls Locker Rm S. Sh Tower 1, #4	20870601-004SH	Exempt	
Girls Locker Rm S. Sh Tower 1, #5	20870601-005SH	Exempt	
Girls Locker Rm S. Sh Tower 2, #1	20870601-006SH	Exempt	
Girls Locker Rm S. Sh Tower 2, #2	20870601-007SH	Exempt	

Girls Locker Rm S. Sh Tower 2, #3	20870601-008SH	Exempt	
Girls Locker Rm S. Sh Tower 2, #4	20870601-009SH	Exempt	
Girls Locker Rm S. Sh Tower 2, #5	20870601-010SH	Exempt	
Girls Locker Rm N. Sh Tower 3, #1	20870601-011SH	Exempt	
Girls Locker Rm N. Sh Tower 3, #2	20870601-012SH	Exempt	
Girls Locker Rm N. Sh Tower 3, #3	20870601-013SH	Exempt	
Girls Locker Rm N. Sh Tower 3, #4	20870601-014SH	Exempt	
Girls Locker Rm N. Sh Tower 3, #5	20870601-015SH	Exempt	
Girls Locker Rm N. Sh Tower 4, #1	20870601-016SH	Exempt	
Girls Locker Rm N. Sh Tower 4, #2	20870601-017SH	Exempt	
Girls Locker Rm N. Sh Tower 4, #3	20870601-018SH	Exempt	
Girls Locker Rm N. Sh Tower 4, #4	20870601-019SH	Exempt	
Girls Locker Rm N. Sh Tower 4, #5	20870601-020SH	Exempt	
Girls Locker Rm Bath Faucet, So.	20870601-021BF	9/24/2021	0.00250
Girls Locker Rm Bath Faucet, No.	20870601-022BF	9/24/2021	0.00271
Girls Locker Rm Fountain, South	20870601-023DW	9/24/2021	0.00347
Girls Locker Rm Fountain, North	20870601-024DW	9/24/2021	0.00286
Boys Locker Rm S. Sh Tower 1, #1	20870601-025SH	Exempt	
Boys Locker Rm S. Sh Tower 1, #2	20870601-026SH	Exempt	
Boys Locker Rm S. Sh Tower 1, #3	20870601-027SH	Exempt	
Boys Locker Rm S. Sh Tower 1, #4	20870601-028SH	Exempt	
Boys Locker Rm S. Sh Tower 1, #5	20870601-029SH	Exempt	
Boys Locker Rm S. Sh Tower 2, #1	20870601-030SH	Exempt	
Boys Locker Rm S. Sh Tower 2, #2	20870601-031SH	Exempt	
Boys Locker Rm S. Sh Tower 2, #3	20870601-032SH	Exempt	
Boys Locker Rm S. Sh Tower 2, #4	20870601-033SH	Exempt	
Boys Locker Rm S. Sh Tower 2, #5	20870601-034SH	Exempt	
Boys Locker Rm N. Sh Tower 3, #1	20870601-035SH	Exempt	
Boys Locker Rm N. Sh Tower 3, #2	20870601-036SH	Exempt	
Boys Locker Rm N. Sh Tower 3, #3	20870601-037SH	Exempt	
Boys Locker Rm N. Sh Tower 3, #4	20870601-038SH	Exempt	
Boys Locker Rm N. Sh Tower 3, #5	20870601-039SH	Exempt	
Boys Locker Rm N. Sh Tower 4, #1	20870601-040SH	Exempt	
Boys Locker Rm N. Sh Tower 4, #2	20870601-041SH	Exempt	

Boys Locker Rm N. Sh Tower 4, #3	20870601-042SH	Exempt	
Boys Locker Rm N. Sh Tower 4, #4	20870601-043SH	Exempt	
Boys Locker Rm N. Sh Tower 4, #5	20870601-044SH	Exempt	
Boys Locker Rm Bath Faucet	20870601-045BF	9/24/2021	ND
Boys Locker Rm Fountain, South	20870601-046DW	9/24/2021	ND
Boys Locker Rm Fountain, North	20870601-047DW	9/24/2021	ND
Gym Back Hall Fountain, East	20870601-048DW	9/24/2021	0.00487
Gym Back Hall Fountain, West	20870601-049DW	9/24/2021	0.00559
Gym Breezeway Boy's Bath Faucet	20870601-050BF	9/24/2021	ND
Gym Breezeway Girls Bath Faucet	20870601-051BF	9/24/2021	ND
Outside Spigot, Behind Gyms	20870601-169OS	Exempt	
O/S Spigot Near Stairs to Girls L/R	20870601-170OS	Exempt	
Science Rm 30 Faucet, 1st on Rt	20870602-080CF	Exempt	
Science Rm 30 Faucet, 2nd on Rt	20870602-081CF	Exempt	
Science Rm 30 Faucet, 3rd on Rt	20870602-082CF	Exempt	
Science Rm 30 Faucet, 4th on Rt	20870602-083CF	Exempt	
Science Rm 30 Faucet, 5th on Rt	20870602-084CF	Exempt	
Science Rm 30 Faucet, 6th on Rt	20870602-085CF	Exempt	
Science Rm 30 Faucet, 7th on Rt	20870602-086CF	Exempt	
Science Rm 31 Faucet, 1st on Left	20870602-087CF	Exempt	
Science Rm 31 Faucet, 2nd on Left	20870602-088CF	Exempt	
Science Rm 31 Faucet, 3rd on Left	20870602-089CF	Exempt	
Science Rm 31 Faucet, 4th on Left	20870602-090CF	Exempt	
Science Rm 31 Faucet, 5th on Left	20870602-091CF	Exempt	
Science Rm 31 Faucet, 6th on Left	20870602-092CF	Exempt	
S. Sci. Wing H/W Fauc., Low Rm #s	20870602-093OT	9/29/2021	ND
S. Sci. Wing H/W Fauc., Mid. Rm #s	20870602-094OT	9/29/2021	ND
S. Sci. Wing H/W Fauc., High Rm #s	20870602-095OT	9/29/2021	ND
Sci. Rm 33 Faucet, 1st on Left	20870602-096CF	Exempt	
Sci. Rm 33 Faucet, 2nd on Left	20870602-097CF	Exempt	
Sci. Rm 33 Faucet, 3rd on Left	20870602-098CF	Exempt	
Sci. Rm 33 Faucet, 4th on Left	20870602-099CF	Exempt	
Sci. Rm 33 Faucet, 5th on Left	20870602-100CF	Exempt	
Sci. Rm 33 Faucet, 6th on Left	20870602-101CF	Exempt	

Sci. Rm 33 Faucet, 7th on Left	20870602-102CF	Exempt	
Sci. Rm 34 Faucet, 1st on Right	20870602-103CF	Exempt	
Sci. Rm 34 Faucet, 2nd on Right	20870602-104CF	Exempt	
Sci. Rm 34 Faucet, 3rd on Right	20870602-105CF	Exempt	
Sci. Rm 34 Faucet, 4th on Right	20870602-106CF	Exempt	
Sci Rm 34 Faucet, 5th on Right	20870602-107CF	Exempt	
Sci. Rm 34 Faucet, 6th on Right	20870602-108CF	Exempt	
Sci. Rm 34 Faucet, 7th on Right	20870602-109CF	Exempt	
Outside Spigot, Outside Rm 34	20870602-110OS	Exempt	
Sci. Rm 36 Faucet, 1st on Right	20870602-111CF	Exempt	
Sci. Rm 36 Faucet, 2nd on Right	20870602-112CF	Exempt	
Sci. Rm 36 Faucet, 3rd on Right	20870602-113CF	Exempt	
Sci. Rm 36 Faucet, 4th on Right	20870602-114CF	Exempt	
Sci. Rm 36 Faucet, 5th on Right	20870602-115CF	Exempt	
Sci. Rm 36 Faucet, 6th on Right	20870602-116CF	Exempt	
Sci. Rm 37 Faucet, 1st on Left	20870602-117CF	Exempt	
Sci. Rm 37 Faucet, 2nd on Left	20870602-118CF	Exempt	
Sci. Rm 37 Faucet, 3rd on Left	20870602-119CF	Exempt	
Sci. Rm 37 Faucet, 4th on Left	20870602-120CF	Exempt	
Sci. Rm 37 Faucet, 5th on Left	20870602-121CF	Exempt	
Sci. Rm 37 Faucet, 6th on Left	20870602-122CF	Exempt	
N. Sci. Wing H/W Fauc., Low Rm #s	20870602-123OT	9/26/2021	0.00456
N. Sci. Wing H/W Fauc., Mid. Rm #s	20870602-124OT	9/26/2021	0.00333
N. Sci. Wing H/W Fauc., High Rm #s	20870602-125OT	9/26/2021	0.00308
Sci. Rm 39 Faucet, 1st on Left	20870602-126CF	Exempt	
Sci. Rm 39 Faucet, 2nd on Left	20870602-127CF	Exempt	
Sci. Rm 39 Faucet, 3rd on Left	20870602-128CF	Exempt	
Sci. Rm 39 Faucet, 4th on Left	20870602-129CF	Exempt	
Sci. Rm 39 Faucet, 5th on Left	20870602-130CF	Exempt	
Sci. Rm 39 Faucet, 6th on Left	20870602-131CF	Exempt	
Sci. Rm 40 Faucet, 1st on Right	20870602-132CF	Exempt	
Sci. Rm 40 Faucet, 2nd on Right	20870602-133CF	Exempt	
Sci. Rm 40 Faucet, 3rd on Right	20870602-134CF	Exempt	
Sci. Rm 40 Faucet, 4th on Right	20870602-135CF	Exempt	

Sci. Rm 40 Faucet, 5th on Right	20870602-136CF	Exempt	
Sci. Rm 40 Faucet, 6th on Right	20870602-137CF	Exempt	
Office Storage Room Faucet	20870602-138OT	9/26/2021	ND
Entryway Fountain	20870602-139DW	9/26/2021	ND
Nurse's Office Shower	20870602-140SH	Exempt	
Nurse's Off. B/R Faucet, O/S of B/R	20870602-141NS	9/26/2021	ND
Nurse's Off. B/R Faucet, I/S of B/R	20870602-142BF	9/26/2021	ND
Nurse's Office Fountain	20870602-143DW	9/26/2021	ND
Copy Room Faucet	20870602-144OT	9/26/2021	ND
Men's B/R Faucet, 1st From Door	20870602-145BF	9/26/2021	ND
Men's B/R Faucet	20870602-146BF	9/26/2021	ND
Ladies B/R Faucet 1st From Door	20870602-147BF	9/26/2021	ND
Ladies B/R Faucet	20870602-148BF	9/26/2021	ND
Handicap Bathroom Faucet	20870602-149BF	9/26/2021	ND
Staff Room Faucet	20870602-150SF	9/26/2021	ND
Staff Room Fountain/Bottle Filler	20870602-151WB	9/26/2021	ND
Library Faucet	20870602-152OT	9/26/2021	ND
Main Hall Fount, Close to Office	20870602-167DW	9/26/2021	ND
Main Hall Fount, Close to Café	20870602-168DW	9/26/2021	ND
O/S Spigot, North of Main Office	20870602-171OS	Exempt	
O/S Spigot, Near N. Main Hall Ent	20870602-172OS	Exempt	
O/S Spigot, Between Rm 30 and 33	20870602-186OS	Exempt	
O/S Spigot, Between Rm 33 and 34	20870602-187OS	Exempt	
O/S Spigot, Between Rm 36 and 39	20870602-188OS	Exempt	
O/S Spigot, Between Rm 39 and 40	20870602-189OS	Exempt	
Custodial Sink, Near Cafeteria	20870604-052OT	Exempt	
Cafeteria Boys Bathroom Faucet	20870604-053BF	9/28/2021	ND
Cafeteria Girls Bathroom Faucet	20870604-054BF	9/24/2021	ND
Cafeteria Fountain, North	20870604-055DW	9/24/2021	ND
Cafeteria Fountain, South	20870604-056DW	9/24/2021	0.00432
Café Breezeway Boys Bath Faucet	20870604-057BF	9/24/2021	ND
Café Breezeway Girls Bath Faucet	20870604-058BF	9/24/2021	ND
Kitchen Bathroom Faucet	20870604-059BF	9/24/2021	ND
Kitchen Faucet, Tray Washing	20870604-060KF	9/24/2021	ND

Kitchen Faucet, Produce Washing	20870604-061KF	9/24/2021	ND
Kitchen Faucet	20870604-062KF	9/24/2021	ND
Kitchen Faucet, Hand Washing	20870604-063KF	9/24/2021	ND
Room 24 Faucet (Technology)	20870604-064CF	9/24/2021	ND
Room 25 Faucet, 1st When in Door	20870604-065CF	9/24/2021	ND
Room 25 Faucet, Back of Room	20870604-066CF	9/24/2021	ND
Room 25 Fountain	20870604-067DW	9/24/2021	ND
Room 26 Faucet	20870604-068CF	9/24/2021	ND
Room 27 Faucet, 1st in Door	20870604-069CF	9/24/2021	ND
Room 27 Faucet, Deep Sink	20870604-070CF	9/24/2021	ND
Room 27 Faucet, Basin	20870604-071CF	9/24/2021	0.00275
Room 28 Faucet, Clockwise #1	20870604-072CF	9/24/2021	ND
Room 28 Faucet, Clockwise #2	20870604-073CF	9/29/2021	0.00308
Room 28 Faucet, Clockwise #3	20870604-074CF	9/29/2021	ND
Room 28 Faucet, Clockwise #4	20870604-075CF	9/29/2021	0.00270
Room 28 Faucet, Clockwise #5	20870604-076CF	9/29/2021	0.00703
Room 28 Faucet, Clockwise #6	20870604-077CF	9/29/2021	0.00293
Room 28 Faucet, Clockwise #7	20870604-078CF	9/17/2021	0.00372
Room 29 Faucet	20870604-079CF	9/29/2021	ND
O/S Spigot, O/S Café, Staff Pking Lot	20870604-180OS	Exempt	
Outside Spigot, Outside Kitchen	20870604-181OS	Exempt	
Outside Spigot, Outside Room 27	20870604-182OS	Exempt	
Outside Spigot, Outside Room 28	20870604-183OS	Exempt	
Outside Spigot, Outside Room 29	20870604-184OS	Exempt	
Outside Spigot, Café South Patio	20870604-185OS	Exempt	
Maintenance Office Bathroom Faucet	20870603-190BF	1/14/2022	ND
Maintenance Office Custodial Sink/Spigot	20870603-191OT	Exempt	
Bus Barn Breakroom Bathroom Faucet	20870603-192BF	1/14/2022	ND
Bus Barn Kitchen Faucet	20870603-193KF	1/14/2022	ND
Bus Barn Mechanic Area Bathroom Faucet	20870603-194BF	1/14/2022	ND
Bus Barn O/S Spigot Behind Building	20870603-195OS	Exempt	
Bus Fueling Station O/S Spigot	20870605-196OT	Exempt	

ND = Non Detect - Lead level is below the set detection limits of 2 ppb



# Water Testing Results - London Elementary School

## Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Classroom 4 Faucet	20870500-001CF	5/26/2021	0.153
Outside Spigot Outside Room 3	20870500-002OS	5/26/2021	2.92
Classroom 3 Faucet	20870500-003CF	5/26/2021	1.68
Fountain Outside Room 3	20870500-004DW	5/26/2021	1.41
Classroom 1 Faucet	20870500-005CF	5/26/2021	0.139
Outside Spigot Outside Room 1	20870500-006OS	5/26/2021	0.132
Outside Spigot Outside Storage Rm	20870500-007OS	5/26/2021	0.149
Storage Room Faucet	20870500-008OT	5/26/2021	0.191
Girls Bathroom Faucet	20870500-009BF	5/26/2021	0.506
Boys Bathroom Faucet	20870500-010BF	5/26/2021	0.654
Furnace Room Faucet	20870500-011OT	5/26/2021	0.135
Fountain Outside Furnace Room	20870500-012DW	5/26/2021	15.1
Staff Bathroom Faucet	20870500-013BF	5/26/2021	0.641
Office Bathroom Faucet	20870500-014BF	5/26/2021	0.152
Classroom 5 Faucet	20870500-015CF	5/26/2021	1.08
Kitchen Faucet	20870500-016KF	5/26/2021	0.679
Outside Spigot Outside Kitchen	20870500-017OS	5/26/2021	0.569
Staffroom Faucet	20870500-018SF	5/26/2021	0.513
Outside Spigot Outside Library	20870500-019OS	5/26/2021	0.507
Geo Dome Bathroom Faucet	20870502-020BF	5/26/2021	0.512
Geo Dome Faucet	20870502-021CF	5/26/2021	0.497
Retest			
Fountain Outside Furnace Room	20870500-012DW		Fixture Disabled

ND = Non Detect - Lead level is below the set detection limits of 2 ppb

